



City of West Kelowna

2760 Cameron Road, West Kelowna, British Columbia V1Z 2T6

Tel (778)797.1000 Fax (778)797.1001

WEST KELOWNA BULK WATER STATION

OPERATING PROCEDURES

1. Connect all hoses and ensure all fittings are tightly secured: **NOTE:** either a 1" or 3" cam-lock is required.(female)
2. Follow the prompts on key pad:
 - a) Select fill type – truck fill (large) or barrel fill (small);
 - b) Enter 3 digit access code obtained from the City of West Kelowna offices at 2760 Cameron Rd (or by email at ub.finance@westkelownacity.ca)
 - c) Enter 4 digit PIN;
 - d) Enter volume required (refer to conversion table below)
 - e) Double check all hoses and fittings; and
 - f) Press START
3. The unit can be stopped at any time by pressing **STOP**; once stopped, the station resets and must be started by re-entering all information.
4. Only the actual pumped volume will be charged, not the volume entered into keypad.

FOR YOUR SAFETY

1. In the event of an overfill press **STOP** on the keypad.
2. Ensure all hoses and fittings are the correct size and in good working condition.
3. Avoid standing directly in front of the hose at the point of connection while filling.
4. Disconnect hoses when done.

CONVERSION TABLE

Conversion: 264 U.S.gallons = 1 cubic metre (1000L)

U.S.Gallons	Cubic Metres (1,000L)
500	1.9
1,000	3.8
2,000	7.57
3,000	11.3
4,000	15.1
5,000	18.9