

RWTP Daily Water Quality Averages

February, 2025	Daily Raw Water NTU	Daily Treated Water NTU	Daily Cl2 Average to Distribution	Daily Average pH to Distribution
February 1, 2025	0.53	0.02	0.88	7.68
February 2, 2025	0.55	0.02	0.87	7.63
February 3, 2025	0.56	0.02	0.88	7.58
February 4, 2025	0.43	0.03	0.90	7.56
February 5, 2025	0.41	0.03	0.88	7.62
February 6, 2025	0.43	0.03	0.89	7.60
February 7, 2025	0.42	0.02	0.88	7.57
February 8, 2025	0.38	0.02	0.86	7.55
February 9, 2025	0.36	0.02	0.81	7.67
February 10, 2025	0.28	0.02	0.91	7.83
February 11, 2025	0.40	0.05	0.70	7.79
February 12, 2025	0.22	0.07	0.85	7.81
February 13, 2025	0.26	0.06	0.97	7.73
February 14, 2025	0.28	0.03	1.04	7.72
February 15, 2025	0.28	0.01	1.04	7.75
February 16, 2025	0.31	0.01	1.01	7.76
February 17, 2025	0.34	0.01	1.04	7.73
February 18, 2025	0.29	0.02	0.98	7.73
February 19, 2025	0.17	0.02	0.93	7.71
February 20, 2025	0.23	0.02	0.92	7.67
February 21, 2025	0.18	0.02	0.98	7.65
February 22, 2025	0.14	0.02	0.98	7.61
February 23, 2025	0.15	0.01	1.00	7.59
February 24, 2025	0.19	0.02	0.97	7.57
February 25, 2025	0.17	0.02	0.92	7.57
February 26, 2025	0.14	0.02	0.89	7.58
February 27, 2025	0.13	0.02	0.84	7.59
February 28, 2025	0.18	0.02	0.91	7.59
Total Monthly Flow to Distribution: 181.55 ML				

Shannon Way Water Quality

Tallus Reservoir

Date	Turbidity	Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		FCR	pH	Date	Turbidity	Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		FCR	pH
	Grab Sample (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)			Grab Sample (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)	
1-Feb-25									1-Feb-25								
2-Feb-25									2-Feb-25								
3-Feb-25	0.16	6.7	<1	<1			0.26		3-Feb-25	0.12	4.3	<1	<1			1.10	
4-Feb-25									4-Feb-25								
5-Feb-25									5-Feb-25	0.15	4.0					1.03	
6-Feb-25									6-Feb-25								
7-Feb-25									7-Feb-25	0.13	4.1					0.92	
8-Feb-25									8-Feb-25								
9-Feb-25									9-Feb-25								
10-Feb-25	0.08	3.9			<1	<1	0.43		10-Feb-25	0.13	2.5			<1	<1	0.83	
11-Feb-25	0.12	6.0					0.37		11-Feb-25	0.14	4.2					0.26	
12-Feb-25									12-Feb-25	0.10	3.5					0.81	
13-Feb-25									13-Feb-25								
14-Feb-25									14-Feb-25	0.25	6.3					0.74	
15-Feb-25									15-Feb-25								
16-Feb-25									16-Feb-25								
17-Feb-25									17-Feb-25								
18-Feb-25	0.10	4.2	<1	<1			0.58		18-Feb-25	0.21	3.6	<1	<1			0.70	
19-Feb-25									19-Feb-25								
20-Feb-25									20-Feb-25								
21-Feb-25									21-Feb-25								
22-Feb-25									22-Feb-25								
23-Feb-25									23-Feb-25								
24-Feb-25									24-Feb-25								
25-Feb-25	0.09	5.4	<1	<1			0.36	7.58	25-Feb-25	0.16	3.9	<1	<1			0.45	7.63
26-Feb-25									26-Feb-25								
27-Feb-25									27-Feb-25								
28-Feb-25									28-Feb-25	0.17	4.1					0.43	7.47

Lakeview Cove PS

Rosewood PS Water Quality

Date	Turbidity Calibration Confirmation		Water Temp	FCR Calibration Confirmation		pH	Date	Turbidity		Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		FCR		pH
	Grab Sample (NTU)	Online Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Online Sample (mg/L)			Grab Sample (NTU)	Online Sample (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)	Online Sample (mg/L)	
1-Feb-25							1-Feb-25										
2-Feb-25							2-Feb-25										
3-Feb-25	0.26	0.35	8.5	0.57	0.39		3-Feb-25	0.13	0.07	4.8	<1	<1			0.88	0.71	
4-Feb-25							4-Feb-25										
5-Feb-25	0.28	0.42	8.8	0.48	0.33		5-Feb-25	0.13		4.5					0.91	0.71	7.64
6-Feb-25							6-Feb-25										
7-Feb-25	0.08	0.35	7.1	0.53	0.34	6.92	7-Feb-25	0.13	0.07	4.5					0.79	0.66	7.67
8-Feb-25							8-Feb-25										
9-Feb-25							9-Feb-25										
10-Feb-25							10-Feb-25	0.13				<1	<1		0.80		
11-Feb-25	0.39		6.4	0.62			11-Feb-25	0.09		3.5					0.87		
12-Feb-25	0.3	0.4	6.6	0.6	0.53		12-Feb-25	0.12	0.06	3.9					0.80	0.72	
13-Feb-25							13-Feb-25										
14-Feb-25	0.18	0.36	7.1	0.21	0.22		14-Feb-25	0.17	0.06	4.0					0.94		
15-Feb-25							15-Feb-25										
16-Feb-25							16-Feb-25										
17-Feb-25							17-Feb-25										
18-Feb-25	0.21	0.4	7.1	0.47	0.49		18-Feb-25	0.22	0.07	4.3	<1	<1			1.08	0.90	7.65
19-Feb-25							19-Feb-25										
20-Feb-25	0.14	0.35	6.5	0.91	0.82		20-Feb-25	0.15	0.06	4.1					0.81	0.77	7.73
21-Feb-25							21-Feb-25										
22-Feb-25							22-Feb-25										
23-Feb-25							23-Feb-25										
24-Feb-25	0.17	0.35	6.4	0.86	0.87	7.66	24-Feb-25										
25-Feb-25							25-Feb-25	0.10	0.10	4.4	<1	<1			0.92	1.24	7.56
26-Feb-25							26-Feb-25										
27-Feb-25							27-Feb-25										
28-Feb-25							28-Feb-25	0.07		4.7					0.78		7.52

Blackwood Water Quality										McPhail Water Quality									
Date	Turbidity Calibration Confirmation		Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		FCR Calibration Confirmation		pH	Date	Turbidity	Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		Free Chlorine Residual	pH
	Grab Sample (NTU)	Online Analyser (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)	Online Sample (mg/L)			Grab Sample (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)	
1-Feb-25											1-Feb-25								
2-Feb-25											2-Feb-25								
3-Feb-25	0.10	0.11	4.8	<1	<1			0.60	0.75	7.76	3-Feb-25	0.10	4.3	<1	<1			0.40	
4-Feb-25											4-Feb-25								
5-Feb-25	0.11	0.11	4.5					0.53	0.68	7.70	5-Feb-25	0.13	5.4					0.44	
6-Feb-25											6-Feb-25								
7-Feb-25	0.19	0.12	4.6					0.63	0.67	7.70	7-Feb-25	0.25	4.6					0.39	
8-Feb-25											8-Feb-25								
9-Feb-25											9-Feb-25								
10-Feb-25	0.18	0.12	4.6			<1	<1	0.57	0.58	7.68	10-Feb-25	0.15	5.6			<1	<1	0.42	
11-Feb-25											11-Feb-25	0.12	5.1					0.37	
12-Feb-25	0.50	0.50	4.5					0.69	0.63	7.77	12-Feb-25	0.26	3.9					0.46	
13-Feb-25											13-Feb-25								
14-Feb-25	0.21	0.14	4.4					0.58	0.58	7.79	14-Feb-25	0.29	5.2					0.50	
15-Feb-25											15-Feb-25	.							
16-Feb-25											16-Feb-25								
17-Feb-25											17-Feb-25								
18-Feb-25	0.17	0.15	4.8	<1	<1			0.80	0.82	7.73	18-Feb-25	0.18	5.5	<1	<1			0.52	
19-Feb-25											19-Feb-25								
20-Feb-25	0.08	0.16	5.0					0.70	1.47	7.66	20-Feb-25	0.11	4.5					0.45	7.81
21-Feb-25											21-Feb-25								
22-Feb-25											22-Feb-25								
23-Feb-25											23-Feb-25								
24-Feb-25											24-Feb-25								
25-Feb-25	0.07	0.06	5.1	<1	<1			0.61	0.73	7.62	25-Feb-25	0.12	5.4	<1	<1			0.64	
26-Feb-25											26-Feb-25								
27-Feb-25											27-Feb-25								
28-Feb-25	0.15		4.7					0.69		7.45	28-Feb-25	0.21	5.4					0.45	7.38

Lower Horizon Water Quality								Pettman Water Quality					
Date	Turbidity	Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		Free Chlorine Residual	pH	Date	Turbidity	Water Temp	Free Chlorine Residual	pH
	Grab Sample (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)			Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	
1-Feb-25									1-Feb-25				
2-Feb-25									2-Feb-25				
3-Feb-25	0.09	5.2	<1	<1			0.42		3-Feb-25	0.16	5.8	0.69	
4-Feb-25									4-Feb-25				
5-Feb-25									5-Feb-25	0.13	7.0	0.55	
6-Feb-25									6-Feb-25				
7-Feb-25	0.20	6.3					0.36		7-Feb-25	0.10	6.6	0.64	
8-Feb-25									8-Feb-25				
9-Feb-25									9-Feb-25				
10-Feb-25	0.16	5.4			<1	<1	0.43		10-Feb-25				
11-Feb-25	0.08	5.6					0.40		11-Feb-25				
12-Feb-25									12-Feb-25	0.77	6.0	0.69	
13-Feb-25									13-Feb-25				
14-Feb-25	0.61	5.4					0.49		14-Feb-25	0.27	8.2	0.58	
15-Feb-25									15-Feb-25				
16-Feb-25									16-Feb-25				
17-Feb-25									17-Feb-25				
18-Feb-25	0.17	5.0	<1	<1			0.54		18-Feb-25	0.19	5.8	0.23	
19-Feb-25									19-Feb-25				
20-Feb-25	0.13	5.5					0.63	7.40	20-Feb-25	0.13	11.0	0.29	
21-Feb-25									21-Feb-25				
22-Feb-25									22-Feb-25				
23-Feb-25									23-Feb-25				
24-Feb-25									24-Feb-25	0.26	9.8	0.63	7.87
25-Feb-25	0.11	4.3	<1	<1			0.45	7.39	25-Feb-25				
26-Feb-25									26-Feb-25				
27-Feb-25									27-Feb-25				
28-Feb-25									28-Feb-25	0.22	7.6	0.52	7.58

Vineyard View Dr Water Quality								Boucherie Pump Station Water Quality								
Date	Turbidity	Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		Free Chlorine Residual	pH	Date	Turbidity	Outlet Water Temp	Inlet FCR Calibration Confirmation		Outlet FCR Calibration Confirmation		pH
	Grab Sample (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)			Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Online Sample (mg/L)	Grab Sample (mg/L)	Online Sample (mg/L)	
1-Feb-25									1-Feb-25							
2-Feb-25									2-Feb-25							
3-Feb-25	0.18	4.6	<1	<1			0.31		3-Feb-25	0.42	15.3	0.43	0.33	0.32	0.19	
4-Feb-25									4-Feb-25							
5-Feb-25									5-Feb-25	0.17	6.8	0.39	0.38	1.04	0.88	
6-Feb-25									6-Feb-25							
7-Feb-25									7-Feb-25	0.23	7.5	1.08	0.94	0.79	0.73	
8-Feb-25									8-Feb-25							
9-Feb-25									9-Feb-25							
10-Feb-25	0.13	6.7			<1	<1	0.42		10-Feb-25							
11-Feb-25									11-Feb-25							
12-Feb-25									12-Feb-25	0.43	12.6	0.48	0.35	0.29	0.27	
13-Feb-25									13-Feb-25							
14-Feb-25									14-Feb-25	0.38	12.4	1.45	1.46	0.66	0.73	
15-Feb-25									15-Feb-25							
16-Feb-25									16-Feb-25							
17-Feb-25									17-Feb-25							
18-Feb-25									18-Feb-25	0.23	8.8	0.77	0.76	0.41	0.58	
19-Feb-25									19-Feb-25							
20-Feb-25									20-Feb-25	0.23	13.3	1.15	1.09			7.62
21-Feb-25									21-Feb-25							
22-Feb-25									22-Feb-25							
23-Feb-25									23-Feb-25							
24-Feb-25									24-Feb-25							
25-Feb-25	0.09	5.1	<1	<1			0.43	7.52	25-Feb-25							
26-Feb-25									26-Feb-25							
27-Feb-25									27-Feb-25							
28-Feb-25									28-Feb-25							

Upper Boucherie Reservoir Water Quality								Sunnyside SS							
Date	Turbidity	Water Temp	Bacteriological (Caro)		FCR Calibration Confirmation		pH	Date	Turbidity	Water Temp	Bacteriological		Bacteriological (Colilert)		FCR
	Grab Sample (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)	Online Sample (mg/L)			Grab Sample (NTU)	Grab Sample (Deg C)	E.coli/100 mL	Total Coliform /100 mL	E.coli/100 mL	Total Coliform /100 mL	Grab Sample (mg/L)
1-Feb-25								1-Feb-25							
2-Feb-25								2-Feb-25							
3-Feb-25	0.22	4.1			0.39	0.43		3-Feb-25	0.14	6.0	<1	<1			0.20
4-Feb-25								4-Feb-25							
5-Feb-25	0.12	5.6			0.31	0.41		5-Feb-25							
6-Feb-25								6-Feb-25							
7-Feb-25	0.12	3.7			0.42	0.56	6.86	7-Feb-25							
8-Feb-25								8-Feb-25							
9-Feb-25								9-Feb-25							
10-Feb-25								10-Feb-25	0.25	6.8			<1	<1	0.22
11-Feb-25								11-Feb-25	0.25	5.8					0.24
12-Feb-25	0.14	4.1			0.30	0.34		12-Feb-25							
13-Feb-25								13-Feb-25							
14-Feb-25	0.21	3.7			0.34	0.49		14-Feb-25							
15-Feb-25								15-Feb-25							
16-Feb-25								16-Feb-25							
17-Feb-25								17-Feb-25							
18-Feb-25	0.16	3.2			0.41	0.58	7.94	18-Feb-25	0.16	5.9	<1	<1			0.30
19-Feb-25								19-Feb-25							
20-Feb-25	0.15	4.2			0.44	0.69	7.62	20-Feb-25							
21-Feb-25								21-Feb-25							
22-Feb-25								22-Feb-25							
23-Feb-25								23-Feb-25							
24-Feb-25	0.20	4.4			0.64	0.85	7.71	24-Feb-25							
25-Feb-25	0.11	4.7	<1	<1	0.58	0.58	7.62	25-Feb-25	0.21	6.4	<1	<1			0.37
26-Feb-25								26-Feb-25							
27-Feb-25								27-Feb-25							
28-Feb-25								28-Feb-25							

Green Bay Sample Tap

Date	Turbidity	Water Temp	Bacteriological		Bacteriological (Colilert)		FCR
	Grab Sample (NTU)	Grab Sample (Deg C)	E.coli/100 mL	Total Coliform /100 mL	E.coli/100 mL	Total Coliform /100 mL	Grab Sample (mg/L)
1-Feb-25							
2-Feb-25							
3-Feb-25	0.35	5.0	<1	<1			0.49
4-Feb-25							
5-Feb-25							
6-Feb-25							
7-Feb-25							
8-Feb-25							
9-Feb-25							
10-Feb-25	0.12	6.7			<1	<1	0.52
11-Feb-25	0.13	5.0					0.47
12-Feb-25							
13-Feb-25							
14-Feb-25							
15-Feb-25							
16-Feb-25							
17-Feb-25							
18-Feb-25	0.22	5.3	<1	<1			0.55
19-Feb-25							
20-Feb-25							
21-Feb-25							
22-Feb-25							
23-Feb-25							
24-Feb-25							
25-Feb-25	0.33	5.1	<1	<1			0.54
26-Feb-25							
27-Feb-25							
28-Feb-25							

PCWTP Daily Water Quality Averages

	Daily Raw Water NTU Avg.	Daily Treated Water NTU Avg	Daily Avg. Cl2 Residual to Distribution	Daily Avg. pH to Distribution
February 1, 2025	1.39	0.02	1.08	7.71
February 2, 2025	0.97	0.02	1.08	7.71
February 3, 2025	0.86	0.02	1.06	7.71
February 4, 2025	0.90	0.02	0.94	7.70
February 5, 2025	0.92	0.02	0.90	7.69
February 6, 2025	1.03	0.03	0.81	7.60
February 7, 2025	1.03	0.03	0.80	7.48
February 8, 2025	1.09	0.03	0.89	7.50
February 9, 2025	1.12	0.03	0.89	7.49
February 10, 2025	1.11	0.03	0.92	7.62
February 11, 2025	1.10	0.03	0.93	7.70
February 12, 2025	1.14	0.03	0.92	7.71
February 13, 2025	1.18	0.03	0.94	7.70
February 14, 2025	1.20	0.03	0.95	7.69
February 15, 2025	1.17	0.03	1.00	7.71
February 16, 2025	1.14	0.03	0.98	7.71
February 17, 2025	1.12	0.03	0.96	7.70
February 18, 2025	1.10	0.03	1.02	7.70
February 19, 2025	1.01	0.03	0.99	7.70
February 20, 2025	0.98	0.03	0.94	7.69
February 21, 2025	0.93	0.03	0.93	7.73
February 22, 2025	0.89	0.03	0.92	7.71
February 23, 2025	0.88	0.03	0.88	7.72
February 24, 2025	0.98	0.03	0.89	7.70
February 25, 2025	0.94	0.03	0.88	7.73
February 26, 2025	0.96	0.03	0.89	7.71
February 27, 2025	0.97	0.03	0.88	7.72
February 28, 2025	1.69	0.03	0.96	8.57
Total Monthly Flow to Distribution: 177.73 ML				

Lateral One Water Quality											Old Okanagan Sample Station							
Date	Turbidity	Analyser Turbidity	Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		Free Chlorine Residual	Analyser Free Residual	pH	Date	Turbidity	Water Temp	Bacteriological (Caro)		Bacteriological (Colilert)		Free Chlorine Residual
	Grab Sample (NTU)	Online (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)	Online Sample (mg/L)			Grab Sample (NTU)	Grab Sample (Deg C)	E.coli /100 mL	Total Coliform /100 mL	E.coli /100 mL	Total Coliform /100 mL	Grab Sample (mg/L)
1-Feb-25											1-Feb-25							
2-Feb-25											2-Feb-25							
3-Feb-25	0.10	0.12	5.9	<1	<1			0.97	0.95		3-Feb-25	0.16	8.9	<1	<1			0.54
4-Feb-25											4-Feb-25							
5-Feb-25	0.10	0.08	2.5					0.84	0.78		5-Feb-25							
6-Feb-25											6-Feb-25							
7-Feb-25	0.10	0.08	2.7					0.80	0.75	6.99	7-Feb-25							
8-Feb-25											8-Feb-25							
9-Feb-25											9-Feb-25							
10-Feb-25	0.07	0.09	2.2			<1	<1	0.86	0.86		10-Feb-25	0.18	10.0			<1	<1	0.16
11-Feb-25											11-Feb-25							
12-Feb-25	0.06	0.08	2.0					0.90	0.87	7.83	12-Feb-25							
13-Feb-25											13-Feb-25							
14-Feb-25	0.15	0.08	2.0					0.83	0.89	7.79	14-Feb-25							
15-Feb-25											15-Feb-25							
16-Feb-25											16-Feb-25							
17-Feb-25											17-Feb-25							
18-Feb-25	0.08	0.08	1.4	<1	<1			0.94	1.01		18-Feb-25	0.29	8.1	<1	<1			0.23
19-Feb-25											19-Feb-25							
20-Feb-25	0.12	0.05	4.1					0.94	0.95	7.57	20-Feb-25							
21-Feb-25											21-Feb-25							
22-Feb-25											22-Feb-25							
23-Feb-25											23-Feb-25							
24-Feb-25											24-Feb-25							
25-Feb-25	0.08	0.10	4.1	<1	<1			0.83	0.89	7.68	25-Feb-25	0.20	6.3	<1	<1			0.30
26-Feb-25											26-Feb-25							
27-Feb-25											27-Feb-25							
28-Feb-25	0.12		4.0					0.70		7.75	28-Feb-25							

SCR Water Quality					SCPS Water Quality					
Date	Turbidity	Water Temp	Free Chlorine Residual	pH	Date	Turbidity	Water Temp	Free Chlorine Residual	Analyser Free Residual	pH
	Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)			Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Online Sample (mg/L)	
1-Feb-25					1-Feb-25					
2-Feb-25					2-Feb-25					
3-Feb-25	0.22	2.5	0.41		3-Feb-25	0.23	8.3	0.49	0.47	
4-Feb-25					4-Feb-25					
5-Feb-25	0.13	2.7	0.43		5-Feb-25	0.28	8.5	0.50	0.44	
6-Feb-25					6-Feb-25					
7-Feb-25	0.09		0.39	7.04	7-Feb-25	0.21	8.2	0.49	0.39	7.17
8-Feb-25					8-Feb-25					
9-Feb-25					9-Feb-25					
10-Feb-25					10-Feb-25					
11-Feb-25					11-Feb-25					
12-Feb-25	0.19	2.9	0.41		12-Feb-25	0.16	7.8	0.46	0.38	7.8
13-Feb-25					13-Feb-25					
14-Feb-25	0.14	2.0	0.39		14-Feb-25	0.27	6.9	0.39	0.31	7.3
15-Feb-25					15-Feb-25					
16-Feb-25					16-Feb-25					
17-Feb-25					17-Feb-25					
18-Feb-25	0.14	1.5	0.65	7.50	18-Feb-25	0.13	4.2	0.39	0.37	7.45
19-Feb-25					19-Feb-25					
20-Feb-25	0.23	3.2	0.46	7.19	20-Feb-25	0.21	7.4	0.44	0.32	7.46
21-Feb-25					21-Feb-25					
22-Feb-25					22-Feb-25					
23-Feb-25					23-Feb-25					
24-Feb-25	0.32	3.0	0.40	7.87	24-Feb-25	0.19	7.2	0.32	0.26	7.59
25-Feb-25					25-Feb-25					
26-Feb-25					26-Feb-25					
27-Feb-25					27-Feb-25					
28-Feb-25					28-Feb-25	0.28	4.1	0.35		7.44

Dixie Reservoir						Glenrosa Reservoir					
Date	Turbidity	Water Temp	Free Chlorine Residual	Analyser Free Residual	pH	Date	Turbidity	Water Temp	Free Chlorine Residual	Analyser Free Residual	pH
	Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Online Sample (mg/L)			Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Online Sample (mg/L)	
1-Feb-25						1-Feb-25					
2-Feb-25						2-Feb-25					
3-Feb-25	0.21	5.30	0.55	0.63		3-Feb-25	0.08	2.00	0.64	0.65	
4-Feb-25						4-Feb-25					
5-Feb-25	0.12	5.10	0.48	0.58		5-Feb-25	0.1	2.50	0.61	0.59	
6-Feb-25						6-Feb-25					
7-Feb-25	0.13	5.10	0.5	0.61	7.20	7-Feb-25	0.12	1.60	0.77	0.75	6.99
8-Feb-25						8-Feb-25					
9-Feb-25						9-Feb-25					
10-Feb-25						10-Feb-25					
11-Feb-25						11-Feb-25					
12-Feb-25	0.13	4.70	0.48	0.56		12-Feb-25	0.05	1.70	0.56	0.56	7.65
13-Feb-25						13-Feb-25					
14-Feb-25	0.18	4.00	0.43	0.58		14-Feb-25	0.16	1.80	0.47	0.55	7.68
15-Feb-25						15-Feb-25					
16-Feb-25						16-Feb-25					
17-Feb-25						17-Feb-25					
18-Feb-25	0.22	4.20	0.37	0.55	7.71	18-Feb-25	0.2	1.90	0.53	0.60	7.73
19-Feb-25						19-Feb-25					
20-Feb-25	0.14	4.40	0.44	0.52	7.42	20-Feb-25	0.58	2.00	0.69	0.58	7.26
21-Feb-25						21-Feb-25					
22-Feb-25						22-Feb-25					
23-Feb-25						23-Feb-25					
24-Feb-25	0.12	4.70	0.46	0.48	7.84	24-Feb-25	0.07	2.30	0.52	0.53	7.80
25-Feb-25						25-Feb-25					
26-Feb-25						26-Feb-25					
27-Feb-25						27-Feb-25					
28-Feb-25	0.18	4.30	0.43		7.30	28-Feb-25	0.3	3.20	0.82		7.65