

**CITY OF WEST KELOWNA**

# Monthly Water Quality Report



**Powers Creek Water Service Area**

**February 2025**

# WATER SUPPLY AND TREATMENT





# Powers Creek Water Treatment Plant


## Water Quality Summary

February 2025

### Flow Demand

Total Flow	177,728 M <sup>3</sup>
High Day, Feb 9 <sup>th</sup> , 2025	3,229 M <sup>3</sup>
Low Day, Feb 20 <sup>th</sup> , 2025	2,464 M <sup>3</sup>

### Daily Consumption



Date	Raw Water	Filtered Water	Treated & Disinfected Water				
	Intake Total	Backwash Flow	Flow to	City Flow	Glenrosa Flow	Smith Creek	
February 1, 2025	7.0473	0.0000	7.4118	4.8118	1.7598	1.0831	0.0001
February 2, 2025	6.9508	0.0000	7.2463	4.8118	1.6989	1.1087	0.0001
February 3, 2025	7.0026	0.3782	6.7831	4.6281	1.7947	1.0834	0.0001
February 4, 2025	6.8989	0.0000	7.3490	4.6015	1.8871	0.9540	0.0001
February 5, 2025	7.1193	0.3746	6.9361	4.7139	1.6443	1.1053	0.0000
February 6, 2025	6.6840	0.0000	7.0231	4.6046	1.5554	0.9968	0.0001
February 7, 2025	6.9207	0.3755	6.6757	4.6543	1.6974	1.0590	0.0001
February 8, 2025	7.1635	0.0000	7.5257	4.7013	1.8745	1.0399	0.0001
February 9, 2025	7.0706	0.0000	7.3784	4.9928	1.9919	1.2374	0.0001
February 10, 2025	7.2407	0.3784	7.0183	4.7415	1.7664	1.0779	0.0000
February 11, 2025	7.2289	0.0000	7.6811	4.6556	1.8224	1.0168	0.0001
February 12, 2025	6.9342	0.3751	6.7164	4.6556	1.8016	1.1067	0.0001
February 13, 2025	6.7385	0.0000	7.0946	4.7104	1.5849	1.1067	0.0001
February 14, 2025	7.0119	0.3749	6.8307	4.6200	1.6112	1.0699	0.0001
February 15, 2025	6.6073	0.0000	7.0496	4.6304	1.6112	1.0727	0.0001
February 16, 2025	6.4407	0.0000	6.7941	4.6622	1.5951	1.0634	0.0001
February 17, 2025	6.6551	0.0000	7.0519	4.8461	1.5379	1.0634	0.0000
February 18, 2025	6.8050	0.3769	6.8332	4.7735	1.5795	1.0948	0.0001
February 19, 2025	6.8196	0.0000	7.0911	4.6348	1.5176	1.0642	0.0001
February 20, 2025	6.4747	0.0000	6.6984	4.4894	1.5176	0.9468	0.0001
February 21, 2025	7.3000	0.6344	6.5971	4.6907	1.5337	1.0634	0.0001
February 22, 2025	6.7617	0.0000	7.1373	4.7634	1.5686	1.1324	0.0001
February 23, 2025	6.6405	0.0000	6.9763	4.7258	1.5943	1.0636	0.0001
February 24, 2025	6.8271	0.3790	6.7971	4.6081	1.5398	1.0017	0.0001
February 25, 2025	6.7692	0.2151	6.6041	4.6340	1.5398	1.0508	0.0001
February 26, 2025	7.3507	0.3793	7.1880	4.6340	1.6173	1.0240	0.0001
February 27, 2025	6.4234	0.0126	6.9057	4.7108	1.5145	1.0572	0.0001
February 28, 2025	6.8803	0.5702	6.2850	4.6368	1.6272	1.0572	0.0001
<b>Daily Average (ML):</b>	6.8845	0.1723	6.9885	4.6908	1.6566	1.0643	0.0001
<b>Monthly Totals (ML):</b>	192.7672	4.8240	195.6791	131.3431	46.3847	29.8029	
<b>Backwash Water (% of Total):</b>		2.50%					



# Powers Creek Water Treatment Plant

## Water Quality Summary

February 2025

### Chlorine

Chlorine used: **332 kg.**



Average **12 kg/day**

### Free Chlorine Residual Range Leaving Reservoir

Maximum: **1.12 ppm**

Minimum: **0.11 ppm**

Average: **0.94 ppm**



### pH

High: **8.57**

Low: **7.48**

Average: **7.71**

### Raw Water Turbidity

High: **4.01 NTU**

Low: **0.49 NTU**

Average: **1.06 NTU**





# Powers Creek Water Treatment Plant

## Water Quality Summary

February 2025

### Finished Water Turbidity

High: **0.04 NTU**

Low: **0.00 NTU**

Average: **0.03 NTU**

### Chemical Usage

Month	Totals	7210A Total (L)	PACI Total (L)	Chlorine (Kg)	7660A (L)	NaOH Total (L)
		46.39	5,518.45	331.65	302.74	3,678.73

### Operational Highlights:

Demand for February was 177,728 **M<sup>3</sup>** compared to February 2024 demand of 183,202**M<sup>3</sup>**

- **Regular and routine maintenance around PCWTP**

- Annual maintenance on UV system, changed out 2 bulbs – Feb 4<sup>th</sup>
- Annual Fire Extinguisher check by contractor – Feb 6<sup>th</sup>
- DAF polymer make down system clean & flush – Feb 6<sup>th</sup>
- Centrifuge polymer make down system clean & flush – Feb 7<sup>th</sup>
- Annual Caustic pump maintenance – Feb 10<sup>th</sup> & 11<sup>th</sup>
- Changed out UV Optiview bulb – Feb 11<sup>th</sup>
- Swapped out chlorine tonners and charged – Feb 11<sup>th</sup> & 12<sup>th</sup>
- Replaced 20" backwash valve on DAF #6, contractor & staff – Feb 17<sup>th</sup> – 20<sup>th</sup>
- Chemical delivery (PAC) – Feb 24<sup>th</sup>
- Changed out all expired eyewash bottles – Feb 26<sup>th</sup>
- Semi-annual floc tank & polymer system maintenance on train #2 – Feb 27<sup>th</sup> – 28<sup>th</sup>
- Ongoing auto backwash work with Spartan – all month now completed
- Automated Centrifuge control, done by Spartan – all month now complete
- Ongoing Hypo conversion work with Maple Reinders – all month

- **Powers Creek Watershed inspections and maintenance**

No Dam inspections done in February due to snow & ice

- Snow course for Province done February 26<sup>th</sup> – Snow depth 110.3cm 108.55% of 44yr average & total water equivalent 175cm, 64.91% of 44yr average, for this time of year
- Lambly Lake – changed Fuel Cell Feb 14<sup>th</sup>

# WATER DISTRIBUTION



# Power's Creek Water Service Area – Distribution System Monitoring

February 2025

## Water Quality Data Review

- Based on the distribution system sample monitoring data it appears the water quality objectives were met for chlorine, turbidity and bacteriological parameters for the month. One exception on Feb 10<sup>th</sup> 2025 a lower free chlorine residual at the Old Okanagan sample station was noted to be 0.16mg/L due to the low water flow through the PRV during the winter months leading to chlorine decay.
  - Bacteriological Samples:
    - 18 samples to CARO for analysis
    - 6 samples analyzed in-house
    - All bacteriological samples came back at <1 CFU/100mL for Total Coliforms and <1CFU/100mL for *E.coli*
- February 10, 2025 – Bulk Water Station sample tap installed inside the station.

### **Note:**

Water Quality (WQ) Field Data results reflect that of the noted location within the distribution system at the time of the grab sample collection.

## Operational System Improvements/Events

- February 1, 2025 – Leak on 2” service line was identified on Brown Rd near intersection of Dobbin Rd and was temporally repaired however and second excavation will be needed to complete the job.
  - Feb 21, 2025 – Foreman visited all business owners individually and spoke with them regarding the pending main repair that will affect water service on March 4th.
  - Feb 27, 2025 – Letter was hand delivered to all business owners affected by the repair planned March 4<sup>th</sup>.
- February 5, 2025 – 3344 McIver Rd service leak between main and curb stop repaired.
- February 7, 2025 – 3634 Granada Cres, service leak repair on City side between main and curb stop. Planned future long sided service replacement.
- February 10, 2025 – 3468 McTaggart Rd service leak, repaired and planned future replacement of the line from main to curb stop.
- February 12, 2025 – 3325 McQueen Rd service leak, replacement service from main to curb stop.
- February 25, 2025 – Quarterly sampling was done including THMs, HAA, TOC, Metals and LSI

# WQ Field Data and Online Data


## Lateral One PS

### Lateral One PS Online Data

Date	L1 Water pH	L1 Turbidity	L1 Turbidity (Peak 1 Hr)	L1 Water Temp	L1 Chlorine Residual		
	Avg (pH)	Avg (NTU)	Max Based On 1 Hr Avg	Avg (°C)	Min (mg/L)	Max (mg/L)	Avg (mg/L)
<b>February 2025</b>							
1	7.67	0.10	0.10	5.07	0.82	0.94	0.89
2	7.68	0.10	0.10	4.95	0.83	0.95	0.90
3	7.68	0.10	0.10	4.98	0.81	0.95	0.90
4	7.66	0.10	0.15	4.18	0.73	0.90	0.84
5	7.63	0.08	0.10	3.27	0.71	0.84	0.77
6	7.65	0.06	0.06	3.42	0.71	0.84	0.77
7	7.65	0.06	0.07	3.35	0.54	0.82	0.74
8	7.64	0.05	0.05	3.32	0.73	0.89	0.83
9	7.64	0.05	0.05	2.48	0.76	0.88	0.83
10	7.71	0.07	0.11	3.27	0.75	0.91	0.84
11	7.76	0.08	0.08	3.17	0.79	0.94	0.87
12	7.79	0.08	0.08	2.94	0.77	0.93	0.85
13	7.81	0.08	0.08	3.05	0.81	0.93	0.88
14	7.83	0.08	0.08	3.02	0.79	30.00	0.91
15	7.86	0.08	0.08	3.03	0.98	1.17	1.08
16	7.84	0.08	0.08	3.07	0.92	1.08	1.01
17	7.82	0.08	0.08	3.04	0.90	1.04	0.99
18	7.82	0.08	0.08	3.74	0.90	1.05	1.00
19	7.83	0.08	0.09	5.01	0.86	1.03	0.95
20	7.87	0.08	0.09	5.25	0.85	0.95	0.91
21	7.92	0.08	0.08	5.40	0.84	0.98	0.92
22	7.95	0.07	0.07	5.57	0.82	0.99	0.90
23	7.89	0.07	0.07	5.79	0.82	0.95	0.89
24	7.88	0.07	0.07	5.83	0.77	0.96	0.86
25	7.95	0.11	0.17	4.82	0.84	1.07	0.89
26	7.91	0.10	0.13	3.95	0.84	0.90	0.88
27	7.88	0.08	0.08	4.00	0.84	0.90	0.89
28	7.90	0.07	0.08	4.28	0.74	0.90	0.84
<b>Total</b>							
<b>Average</b>	7.79	0.08	0.09	4.04	0.80	1.99	0.89
<b>Min</b>	7.63	0.05	0.05	2.48	0.54	0.82	0.74
<b>Max</b>	7.95	0.11	0.17	5.83	0.98	30.00	1.08

**Lateral One PS Field Data**

Date	Turbidity		Water Temp	Free Chlorine Residual		pH
	Grab Sample (NTU)	Online (NTU)	Grab Sample (°C)	Grab Sample (mg/L)	Online Sample (mg/L)	Grab Sample
3-Feb-25	0.10	0.12	5.9	0.97	0.95	
5-Feb-25	0.10	0.08	2.5	0.84	0.78	
7-Feb-25	0.10	0.08	2.7	0.80	0.75	6.99
10-Feb-25	0.07	0.09	2.2	0.86	0.86	
12-Feb-25	0.06	0.08	2.0	0.90	0.87	7.83
14-Feb-25	0.15	0.08	2.0	0.83	0.89	7.79
18-Feb-25	0.08	0.08	1.4	0.94	1.01	
20-Feb-25	0.12	0.05	4.1	0.94	0.95	7.57
25-Feb-25	0.08	0.10	4.1	0.83	0.89	7.68
28-Feb-25	0.12		4.0	0.70		7.75
<b>Average</b>	0.10	0.08	3.09	0.86	0.88	7.60
<b>Min</b>	0.06	0.05	1.40	0.70	0.75	6.99
<b>Max</b>	0.15	0.12	5.90	0.97	1.01	7.83




# Glenrosa PS & Reservoir

## Glenrosa Pump Station & Reservoir Online Data

Date	Flow Total From PS	Peak Flow From PS	Reservoir Water pH	Reservoir Water Temp	Chlorine Residual		
	(ML)	Max (ML/Day)	Avg (pH)	Avg (°C)	Min (mg/L)	Max (mg/L)	Avg (mg/L)
<b>February 2025</b>							
1	3.22	5.05	7.59	2.07	0.60	0.93	0.68
2	1.72	5.05	7.59	2.02	0.60	0.95	0.69
3	1.81	5.05	7.60	1.98	0.61	0.95	0.70
4	1.84	5.04	7.60	1.92	0.61	0.90	0.68
5	1.68	4.38	7.60	1.84	0.58	4.86	0.66
6	1.55	4.39	7.60	1.84	0.57	0.81	0.63
7	3.24	4.39	7.59	1.79	0.55	0.85	0.62
8	1.83	4.39	7.60	1.79	0.53	0.86	0.63
9	3.54	4.38	7.59	1.76	0.54	0.87	0.63
10	5.30	4.39	7.62	1.73	0.00	0.95	0.64
11	1.82	4.39	7.68	1.69	0.54	0.99	0.66
12	1.80	4.12	7.70	1.66	0.54	0.97	0.66
13	1.58	4.12	7.70	1.68	0.54	1.00	0.65
14	1.61	4.13	7.72	1.70	0.53	0.94	0.65
15	1.61	4.13	7.73	1.74	0.54	1.03	0.67
16	3.06	4.12	7.73	1.81	0.54	0.96	0.65
17	1.53	4.13	7.74	1.85	0.54	0.94	0.64
18	1.61	4.50	7.75	1.88	0.54	0.99	0.66
19	1.50	4.41	7.76	1.93	0.55	0.95	0.64
20	1.51	4.44	7.78	2.00	0.55	1.01	0.64
21	1.53	4.46	7.83	2.05	0.54	0.98	0.64
22	3.08	4.43	7.85	2.13	0.54	1.12	0.64
23	1.59	4.52	7.87	2.21	0.53	1.11	0.63
24	1.54	4.40	7.88	2.30	0.52	1.00	0.62
25	1.49	5.03	7.90	2.37	0.52	1.09	0.61
26	1.66	5.06	7.91	2.44	0.51	1.00	0.59
27	1.46	5.04	7.92	2.51	0.50	1.00	0.58
28	1.67	5.03	7.94	2.62	0.49	1.13	0.58
<b>Total</b>	54	-----	-----	-----	-----	-----	-----
<b>Average</b>	2.05	4.54	7.73	1.98	0.53	1.11	0.64
<b>Min</b>	1.46	4.12	7.59	1.66	0.00	0.81	0.58
<b>Max</b>	5.30	5.06	7.94	2.62	0.61	4.86	0.70

## Glenrosa Reservoir Online Data



## Glenrosa Reservoir Field Data

Date	Turbidity	Water Temp	Free Chlorine Residual		pH
	Grab Sample (NTU)	Grab Sample (°C)	Grab Sample (mg/L)	Online Sample (mg/L)	Grab Sample
3-Feb-25	0.08	2.00	0.64	0.65	
5-Feb-25	0.10	2.50	0.61	0.59	
7-Feb-25	0.12	1.60	0.77	0.75	6.99
12-Feb-25	0.05	1.70	0.56	0.56	7.65
14-Feb-25	0.16	1.80	0.47	0.55	7.68
18-Feb-25	0.20	1.90	0.53	0.60	7.73
20-Feb-25	0.58	2.00	0.69	0.58	7.26
24-Feb-25	0.07	2.30	0.52	0.53	7.80
28-Feb-25	0.30	3.20	0.82		7.65
<b>Average</b>	0.18	2.11	0.62	0.60	7.54
<b>Min</b>	0.05	1.60	0.47	0.53	6.99
<b>Max</b>	0.58	3.20	0.82	0.75	7.80


# Smith Creek Reservoir, Dixie Reservoir & End-of-Line WQS

Date	Smith Creek Reservoir FCR Online Data		
	Min (mg/L)	Max (mg/L)	Avg (mg/L)
<b>February 2025</b>			
1	0.51	0.57	0.54
2	0.48	0.53	0.51
3	0.46	0.51	0.48
4	0.45	0.50	0.47
5	0.43	0.46	0.45
6	0.41	0.46	0.43
7	0.39	0.42	0.41
8	0.37	0.40	0.39
9	0.29	0.40	0.37
10	0.26	0.34	0.30
11	0.25	0.39	0.30
12	0.37	0.40	0.38
13	0.30	0.40	0.38
14	0.30	0.39	0.34
15	0.26	0.32	0.28
16	0.30	0.37	0.35
17	0.35	0.40	0.38
18	0.30	0.40	0.38
19	0.29	0.35	0.31
20	0.29	0.37	0.34
21	0.34	0.37	0.35
22	0.29	0.37	0.36
23	0.29	0.35	0.32
24	0.26	0.32	0.28
25	0.30	0.35	0.33
26	0.00	0.37	0.35
27	0.26	0.35	0.32
28	0.23	0.28	0.25
<b>Average</b>	0.32	0.40	0.37
<b>Min</b>	0.00	0.28	0.25
<b>Max</b>	0.51	0.57	0.54

Dixie Reservoir FCR Online Data		
Min (mg/L)	Max (mg/L)	Avg (mg/L)
0.67	0.72	0.69
0.65	0.68	0.67
0.62	0.67	0.65
0.58	0.64	0.62
0.56	11.82	0.62
0.59	0.68	0.64
0.59	0.64	0.63
0.59	0.62	0.61
0.57	0.66	0.62
0.62	0.64	0.63
0.58	0.63	0.61
0.56	0.59	0.58
0.54	0.62	0.56
0.59	0.62	0.61
0.56	0.61	0.58
0.54	0.57	0.56
0.52	0.56	0.54
0.51	0.59	0.55
0.54	0.58	0.56
0.52	0.56	0.54
0.48	0.53	0.51
0.47	0.55	0.50
0.51	0.55	0.53
0.49	0.53	0.51
0.47	0.51	0.49
0.45	0.48	0.47
0.44	0.51	0.49
0.48	0.51	0.49
0.55	1.00	0.57
0.44	0.48	0.47
0.67	11.82	0.69

End-of-The-Line FCR Online Data		
Min (mg/L)	Max (mg/L)	Avg (mg/L)
0.62	0.64	0.63
0.63	0.71	0.68
0.68	0.71	0.70
0.67	0.71	0.69
0.58	0.67	0.64
0.53	0.59	0.56
0.51	0.55	0.54
0.50	0.53	0.51
0.53	0.61	0.57
0.58	0.61	0.59
0.57	0.60	0.59
0.57	0.62	0.60
0.58	0.60	0.59
0.60	0.63	0.61
0.59	0.61	0.61
0.61	0.67	0.64
0.63	0.70	0.66
0.63	0.68	0.66
0.63	0.65	0.63
0.62	0.68	0.64
0.61	0.65	0.63
0.62	0.64	0.63
0.59	0.63	0.62
0.57	0.60	0.59
0.56	0.58	0.58
0.00	0.60	0.59
0.55	0.59	0.57
0.55	0.59	0.58
0.57	0.63	0.61
0.00	0.53	0.51
0.68	0.71	0.70

## Smith Creek, Dixie, End of Line Online Data



Date	Smith Creek Res Field Data				Smith Creek PS Field Data				
	Turbidity	Water Temp	Free Chlorine Residual	pH	Turbidity	Water Temp	Free Chlorine Residual		pH
	Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Grab Sample	Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Online Sample (mg/L)	Grab Sample
03-Feb-25	0.22	2.50	0.41		0.23	8.30	0.49	0.47	
05-Feb-25	0.13	2.70	0.43		0.28	8.50	0.50	0.44	
07-Feb-25	0.09		0.39	7.04	0.21	8.20	0.49	0.39	7.17
12-Feb-25	0.19	2.90	0.41		0.16	7.80	0.46	0.38	7.80
14-Feb-25	0.14	2.00	0.39		0.27	6.90	0.39	0.31	7.30
18-Feb-25	0.14	1.50	0.65	7.50	0.13	4.20	0.39	0.37	7.45
20-Feb-25	0.23	3.20	0.46	7.19	0.21	7.40	0.44	0.32	7.46
24-Feb-25	0.32	3.00	0.40	7.87	0.19	7.20	0.32	0.26	7.59
28-Feb-25					0.28	4.10	0.35		7.44
<b>Average</b>	0.18	2.54	0.44	7.40	0.22	6.96	0.43	0.37	7.46
<b>Min</b>	0.09	1.50	0.39	7.04	0.13	4.10	0.32	0.26	7.17
<b>Max</b>	0.32	3.20	0.65	7.87	0.28	8.50	0.50	0.47	7.80

**Dixie Res Field Data**

Date	Turbidity	Water Temp	Free Chlorine Residual		pH
	Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Analyser Free Residual (mg/L)	Grab Sample
03-Feb-25	0.21	5.3	0.55	0.63	
05-Feb-25	0.12	5.1	0.48	0.58	
07-Feb-25	0.13	5.1	0.50	0.61	7.20
12-Feb-25	0.13	4.7	0.48	0.56	
14-Feb-25	0.18	4.0	0.43	0.58	
18-Feb-25	0.22	4.2	0.37	0.55	7.71
20-Feb-25	0.14	4.4	0.44	0.52	7.42
24-Feb-25	0.12	4.7	0.46	0.48	7.84
28-Feb-25	0.18	4.3	0.43		7.30
<b>Average</b>	0.16	4.6	0.46	0.56	7.49
<b>Min</b>	0.12	4.0	0.37	0.48	7.20
<b>Max</b>	0.22	5.3	0.55	0.63	7.84

**End-of-Line Field Data**

Date	Turbidity	Water Temp	Free Chlorine Residual		pH
	Grab Sample (NTU)	Grab Sample (Deg C)	Grab Sample (mg/L)	Online Sample (mg/L)	Grab Sample
03-Feb-25	0.17	5.5	0.82	0.64	
10-Feb-25	0.07	9.4	0.63	0.6	
18-Feb-25	0.06	4.6	0.74	0.66	
25-Feb-25	0.14	4.6	0.6	0.58	7.58
<b>Average</b>	0.11	6.03	0.70	0.62	7.58
<b>Min</b>	0.06	4.60	0.60	0.58	7.58
<b>Max</b>	0.17	9.40	0.82	0.66	7.58

# WQ Field Data

## Old Okanagan SS, Webber SS & Mclver SS

**Old Okanagan SS Field Data**

**Webber SS Field Data**

**Mclver SS Field Data**

Date	Turbidity	Water Temp	Free Chlorine Residual	Turbidity	Water Temp	Free Chlorine Residual	Turbidity	Water Temp	Free Chlorine Residual	pH
	Grab Sample (NTU)	Grab Sample (°C)	Grab Sample (mg/L)	Grab Sample (NTU)	Grab Sample (°C)	Grab Sample (mg/L)	Grab Sample (NTU)	Grab Sample (°C)	Grab Sample (mg/L)	
03-Feb-25	0.16	8.90	0.54	0.19	3.40	0.76	0.07	3.40	0.70	
10-Feb-25	0.18	10.00	0.16	0.08	4.10	0.81	0.10	4.20	0.58	
18-Feb-25	0.29	8.10	0.23	0.07	2.70	0.68	0.11	2.80	0.55	
25-Feb-25	0.20	6.30	0.30	0.11	2.90	0.88	0.12	3.30	0.49	7.64
<b>Average</b>	0.21	8.33	0.31	0.11	3.28	0.78	0.10	3.43	0.58	7.64
<b>Min</b>	0.16	6.30	0.16	0.07	2.70	0.68	0.07	2.80	0.49	7.64
<b>Max</b>	0.29	10.00	0.54	0.19	4.10	0.88	0.12	4.20	0.70	7.64

**Bulk Water Station Field Data**

Date	Turbidity	Water Temp	Free Chlorine Residual	pH
	Grab Sample (NTU)	Grab Sample (°C)	Grab Sample (mg/L)	Grab Sample
3-Feb-25	0.14	5.20	0.69	
5-Feb-25	0.23	5.20	0.55	
7-Feb-25	0.13	5.90	0.49	
10-Feb-25	0.21	4.20	0.35	
12-Feb-25	0.10	5.90		
14-Feb-25	0.22	3.90	0.45	
18-Feb-25	0.29	5.50	0.37	
20-Feb-25	0.17	6.00	0.42	7.54
25-Feb-25	0.14	17.00	0.46	
<b>Average</b>	0.18	6.53	0.47	7.54
<b>Min</b>	0.10	3.90	0.35	7.54
<b>Max</b>	0.29	17.00	0.69	7.54

# Disinfection Byproducts

## Powers Creek Water Service Area - THM Results (mg/L)

	Lateral One	End-of-Line	Mclver
14-Feb-24	0.0311	0.0423	0.0482
13-May-24	0.0211	0.0272	0.0281
12-Aug-24	0.0368	0.0475	0.0404
27-Nov-24	0.0218	0.0486	0.0552
25-Feb-25	0.0382	0.0402	0.0766
Average	0.0298	0.0412	0.0497

## Powers Creek Water Service Area - HAA5 Results (mg/L)

	Lateral One	End-of-Line	Mclver
14-Feb-24	0.0311	0.0423	0.0482
13-May-24	0.0211	0.0272	0.0281
12-Aug-24	0.0205	0.0242	0.0212
27-Nov-24	0.0264	0.0382	0.0476
25-Feb-25	0.0238	0.0300	0.0351
Average	0.0246	0.0324	0.0360

# Manganese

## Power's Creek Water Service Area - Manganese Results (mg/L)

Location	12-Aug-24	27-Nov-24	25-Feb-25	Average
Lateral One	0.0040	0.0038	0.0044	0.0041
Mclver	0.0012	0.0026	0.0022	0.0020
End-of-Line	0.0013	0.0012	0.0073	0.0033