

CITY OF WEST KELOWNA

Monthly Water Quality Report



Powers Creek Water Service Area

May 2026

WATER SUPPLY AND TREATMENT






Powers Creek Water Treatment Plant Monthly Water Quality Summary

2026-06-03

May, 2026

Flow Demand:

	Total for Month
Raw Processed Water:	637.02 ML
Treated Water :	653.59 ML
Distributed Water :	745.92 ML
Backwash Water :	27.78 ML



Notes:

Flow meter to distribution taken offline May 14th

Raw Water Specifications:

Date	Raw Turbidity (NTU)			Raw pH		
	Min	Max	Average	Min	Max	Average
2026-05-01	0.88	5.05	1.45	7.88	8.16	8.03
2026-05-02	1.35	5.80	1.86	7.96	8.20	8.09
2026-05-03	1.33	4.40	1.70	7.80	8.17	7.97
2026-05-04	1.10	6.43	1.86	7.58	8.03	7.83
2026-05-05	1.07	4.91	1.64	7.82	8.06	7.90
2026-05-06	0.88	5.22	1.44	7.80	8.19	7.96
2026-05-07	0.96	3.45	1.48	7.82	8.20	8.03
2026-05-08	0.78	2.38	1.43	7.70	8.09	7.87
2026-05-09	1.13	4.08	1.57	7.78	8.19	7.96
2026-05-10	1.05	2.94	1.72	7.80	8.15	7.99
2026-05-11	0.54	1.78	1.06	7.71	8.12	7.87
2026-05-12	0.09	2.00	1.27	7.88	8.20	8.00
2026-05-13	1.15	2.21	1.60	7.89	8.02	7.96
2026-05-14	0.76	4.12	1.47	7.66	8.08	7.86
2026-05-15	0.59	1.25	0.93	7.66	8.08	7.89
2026-05-16	0.71	2.66	1.16	7.93	8.26	8.07
2026-05-17	0.61	1.46	1.00	8.06	8.17	8.11
2026-05-18	0.61	1.55	1.04	7.99	8.16	8.07
2026-05-19	0.42	1.30	0.87	7.80	8.21	8.02
2026-05-20	1.12	3.54	1.45	7.84	8.28	8.05
2026-05-21	0.93	2.97	1.13	7.81	8.20	8.04
2026-05-22	0.90	3.83	1.18	7.91	8.26	8.08
2026-05-23	0.85	2.76	1.12	7.89	8.14	8.06
2026-05-24	0.83	2.34	1.19	7.72	8.10	7.92
2026-05-25	0.98	3.36	1.24	7.47	8.02	7.76
2026-05-26	0.92	2.90	1.16	7.85	8.04	7.94
2026-05-27	0.79	2.54	1.08	7.91	8.18	8.02
2026-05-28	0.74	2.70	1.00	7.90	8.31	8.11
2026-05-29	1.28	3.50	2.10	7.77	8.06	7.93
2026-05-30	1.51	6.62	1.89	7.81	8.16	7.97
2026-05-31	1.03	3.00	1.25	7.90	8.25	8.05

Notes:

Raw Water Specifications (Continued):

Date	Raw Temp (°C)			Raw DOC (mg/L)		
	Min	Max	Average	Min	Max	Average
2026-05-01	7.34	10.55	8.87	16.39	16.92	16.65
2026-05-02	8.97	17.60	11.57	16.19	16.53	16.37
2026-05-03	10.92	17.60	13.37	15.53	16.20	15.84
2026-05-04	8.70	17.94	12.14	14.85	15.49	15.21
2026-05-05	8.39	15.64	10.27	14.59	23.83	14.81
2026-05-06	8.85	12.22	10.40	13.78	14.59	14.19
2026-05-07	9.23	13.66	11.45	13.53	16.70	13.78
2026-05-08	9.48	18.38	12.05	13.05	13.63	13.33
2026-05-09	8.61	12.31	10.30	12.94	13.29	13.12
2026-05-10	11.10	18.53	13.95	12.87	13.20	13.05
2026-05-11	9.37	12.40	10.72	12.66	12.91	12.78
2026-05-12	8.90	11.88	10.38	12.16	12.71	12.45
2026-05-13	9.79	11.22	10.36	11.99	12.88	12.27
2026-05-14	8.09	10.47	9.28	13.02	13.64	13.37
2026-05-15	7.81	9.39	8.42	12.28	13.78	12.57
2026-05-16	6.65	9.22	7.84	12.30	12.51	12.39
2026-05-17	8.24	10.62	9.26	12.26	12.56	12.40
2026-05-18	8.61	10.86	9.65	12.17	12.49	12.29
2026-05-19	8.36	17.46	10.85	11.90	12.31	12.11
2026-05-20	8.34	11.84	9.98	11.79	100.14	12.17
2026-05-21	8.29	10.64	9.54	11.53	100.14	11.91
2026-05-22	9.32	12.97	10.69	-8.60	11.85	11.44
2026-05-23	12.36	18.92	16.03	11.35	11.59	11.47
2026-05-24	15.27	19.84	17.46	11.06	11.48	11.32
2026-05-25	11.42	19.77	14.99	10.35	100.11	10.89
2026-05-26	11.21	12.92	11.82	11.05	11.34	11.19
2026-05-27	10.99	14.92	12.16	10.93	11.26	11.13
2026-05-28	11.68	17.84	14.78	10.67	100.16	11.17
2026-05-29	12.85	14.96	13.77	10.85	12.11	11.39
2026-05-30	10.49	12.84	11.62	11.41	19.65	12.13
2026-05-31	10.56	13.04	11.79	1.98	100.22	37.46

Notes:

Raw Water Specifications (Continued):

Date	Raw Cond ($\mu\text{S}/\text{cm}$)			Streaming Current		
	Min	Max	Average	Min	Max	Average
2026-05-01	49.52	72.24	71.90	-7.22	51.07	28.84
2026-05-02	70.92	72.01	71.74	-13.32	50.22	23.42
2026-05-03	69.82	73.08	71.71	-24.77	43.85	20.55
2026-05-04	64.56	74.33	72.58	-26.77	45.21	17.24
2026-05-05	73.55	74.00	73.74	-1.83	48.05	24.20
2026-05-06	69.89	100.54	74.63	-10.20	46.09	24.14
2026-05-07	47.01	79.19	75.04	7.32	51.03	28.46
2026-05-08	52.12	77.48	76.20	-74.53	61.47	17.20
2026-05-09	71.75	78.34	74.06	-25.82	34.10	5.43
2026-05-10	78.43	79.76	78.85	-49.11	31.29	5.06
2026-05-11	79.31	80.79	80.13	-26.77	35.24	14.62
2026-05-12	58.47	83.24	80.82	???	43.92	18.51
2026-05-13	70.34	83.58	82.42	-10.06	50.17	20.28
2026-05-14	69.43	82.82	81.54	-77.72	49.43	3.25
2026-05-15	68.63	82.39	81.84	-29.96	46.07	3.01
2026-05-16	82.40	83.36	82.63	-51.92	50.26	-1.25
2026-05-17	82.93	83.52	83.25	-45.84	49.38	13.71
2026-05-18	83.42	84.56	83.80	-40.96	41.92	17.55
2026-05-19	-0.08	84.79	83.84	-499.92	54.29	13.46
2026-05-20	79.38	86.43	84.34	-29.94	13.57	-9.15
2026-05-21	58.17	87.96	86.78	-29.96	12.24	-7.89
2026-05-22	0.07	88.73	87.95	-51.95	9.45	-10.73
2026-05-23	80.52	89.44	87.52	-58.69	1.86	-32.54
2026-05-24	81.67	90.88	87.75	-60.01	8.21	-22.91
2026-05-25	39.00	91.98	89.87	-32.85	7.35	-11.44
2026-05-26	0.03	92.19	91.82	-38.83	13.67	-7.28
2026-05-27	66.30	92.49	91.99	-99.04	68.57	-19.93
2026-05-28	-0.01	93.06	92.49	-70.59	1.08	-33.93
2026-05-29	74.66	92.29	90.13	-64.82	35.17	-14.43
2026-05-30	88.27	89.33	88.66	-14.01	33.93	2.18
2026-05-31	87.53	89.93	89.14	-55.91	52.36	13.86

Notes:

May 12th - Unit taken out of service for cleaning

Raw Water Specifications (Continued):

Date	Coagulated pH			Coagulated Temp (°C)		
	Min	Max	Average	Min	Max	Average
2026-05-01	6.43	6.49	6.47	7.85	10.05	8.83
2026-05-02	6.49	6.59	6.53	8.57	10.69	9.55
2026-05-03	6.51	6.63	6.54	9.17	12.02	10.47
2026-05-04	6.41	6.62	6.49	8.95	11.29	10.50
2026-05-05	6.45	6.59	6.53	8.70	11.33	9.96
2026-05-06	6.45	6.67	6.55	9.08	11.95	10.46
2026-05-07	6.52	6.57	6.54	9.61	12.48	11.16
2026-05-08	6.52	6.67	6.57	9.56	10.85	10.43
2026-05-09	6.60	6.73	6.67	8.98	12.46	10.50
2026-05-10	6.59	6.65	6.63	10.50	11.87	11.19
2026-05-11	6.55	6.67	6.61	9.53	12.10	10.73
2026-05-12	6.61	6.66	6.63	9.50	13.43	10.61
2026-05-13	6.59	6.66	6.62	10.11	11.03	10.38
2026-05-14	6.61	6.76	6.68	8.38	10.58	9.41
2026-05-15	6.62	6.77	6.70	8.14	9.28	8.57
2026-05-16	6.64	6.80	6.73	6.67	8.64	7.67
2026-05-17	6.61	6.79	6.68	7.35	9.40	8.27
2026-05-18	6.65	6.80	6.69	7.79	9.70	8.77
2026-05-19	6.60	6.68	6.63	8.51	10.31	9.38
2026-05-20	6.61	6.67	6.64	8.63	11.50	9.93
2026-05-21	6.62	6.69	6.65	8.41	10.47	9.48
2026-05-22	6.63	6.73	6.66	9.50	12.03	10.65
2026-05-23	6.65	6.76	6.72	10.53	13.18	11.63
2026-05-24	6.67	6.70	6.68	10.96	13.48	12.11
2026-05-25	6.64	6.67	6.66	11.65	13.22	12.44
2026-05-26	6.62	6.67	6.66	11.43	12.01	11.77
2026-05-27	6.67	6.74	6.71	11.08	12.86	11.80
2026-05-28	6.67	6.75	6.71	11.97	15.28	13.35
2026-05-29	6.68	6.74	6.71	12.63	14.26	13.77
2026-05-30	6.68	6.75	6.72	10.65	12.35	11.56
2026-05-31	6.63	6.79	6.71	10.81	12.84	11.69

Notes:

Train 1 Filter Turbidity (NTU):

Date	Filter 1			Filter 2			Filter 3		
	Min	Max	Average	Min	Max	Average	Min	Max	Average
2026-05-01	0.03	0.09	0.04	0.02	0.03	0.02	0.01	0.08	0.02
2026-05-02	0.03	0.08	0.04	0.02	0.11	0.03	0.01	0.02	0.01
2026-05-03	0.03	0.14	0.04	0.02	0.04	0.02	0.01	0.07	0.02
2026-05-04	0.02	0.05	0.03	0.02	0.07	0.02	0.01	0.01	0.01
2026-05-05	0.02	0.11	0.03	0.02	0.02	0.02	0.01	0.05	0.01
2026-05-06	0.02	0.04	0.03	0.01	0.20	0.02	0.01	0.01	0.01
2026-05-07	0.02	0.12	0.04	0.02	0.06	0.02	0.01	0.06	0.01
2026-05-08	0.02	0.04	0.03	0.01	0.08	0.02	0.01	0.01	0.01
2026-05-09	0.02	0.13	0.03	0.02	0.02	0.02	0.01	0.05	0.01
2026-05-10	0.02	0.06	0.03	0.02	0.07	0.02	0.01	0.01	0.01
2026-05-11	0.02	0.09	0.03	0.01	0.02	0.02	0.01	0.05	0.01
2026-05-12	0.03	0.05	0.03	0.02	0.06	0.02	0.01	0.02	0.01
2026-05-13	0.02	0.16	0.05	0.01	0.03	0.02	0.01	0.05	0.01
2026-05-14	0.02	0.05	0.03	0.02	0.08	0.02	0.01	0.01	0.01
2026-05-15	0.02	0.13	0.03	0.01	0.03	0.02	0.01	0.01	0.01
2026-05-16	0.02	0.03	0.03	0.02	0.08	0.02	0.01	0.06	0.01
2026-05-17	0.02	0.18	0.04	0.02	0.02	0.02	0.01	0.01	0.01
2026-05-18	0.02	0.04	0.03	0.02	0.13	0.03	0.01	0.06	0.02
2026-05-19	0.02	0.23	0.05	0.02	0.03	0.02	0.01	0.01	0.01
2026-05-20	0.02	0.04	0.02	0.01	0.08	0.02	0.01	0.04	0.01
2026-05-21	0.02	0.09	0.03	0.01	0.04	0.02	0.01	0.01	0.01
2026-05-22	0.02	0.05	0.02	0.01	0.05	0.02	0.01	0.04	0.01
2026-05-23	0.02	0.08	0.02	0.01	0.05	0.02	0.01	0.01	0.01
2026-05-24	0.02	0.04	0.02	0.02	0.06	0.02	0.01	0.03	0.01
2026-05-25	0.02	0.05	0.02	0.01	0.03	0.02	0.01	0.01	0.01
2026-05-26	0.02	0.02	0.02	0.02	0.06	0.02	0.01	0.03	0.01
2026-05-27	0.02	0.07	0.02	0.01	0.03	0.02	0.01	0.01	0.01
2026-05-28	0.02	0.05	0.02	0.02	0.06	0.02	0.01	0.03	0.01
2026-05-29	0.00	0.06	0.02	0.02	0.03	0.02	0.01	0.01	0.01
2026-05-30	0.02	0.03	0.02	0.02	0.06	0.02	0.01	0.03	0.01
2026-05-31	0.02	0.04	0.02	0.02	0.03	0.02	0.01	0.01	0.01

Notes:

Train 2 Filter Turbidity (NTU)

Date	Filter 4			Filter 5			Filter 6		
	Min	Max	Average	Min	Max	Average	Min	Max	Average
2026-05-01	0.02	0.05	0.02	0.02	0.04	0.03	0.02	0.08	0.02
2026-05-02	0.02	0.07	0.02	0.03	0.14	0.04	0.02	0.03	0.02
2026-05-03	0.02	0.03	0.02	0.03	0.05	0.03	0.02	0.09	0.03
2026-05-04	0.01	0.06	0.02	0.03	0.10	0.03	0.02	0.03	0.02
2026-05-05	0.01	0.03	0.02	0.02	0.04	0.03	0.01	0.07	0.02
2026-05-06	0.01	0.06	0.02	0.03	0.10	0.04	0.01	0.02	0.02
2026-05-07	0.01	0.02	0.02	0.02	0.04	0.03	0.01	0.79	0.02
2026-05-08	0.02	0.05	0.02	0.02	0.09	0.03	0.01	0.02	0.02
2026-05-09	0.02	0.02	0.02	0.03	0.03	0.03	0.01	0.07	0.02
2026-05-10	0.01	0.05	0.02	0.03	0.11	0.04	0.01	0.02	0.02
2026-05-11	0.01	0.02	0.01	0.03	0.03	0.03	0.02	0.07	0.02
2026-05-12	0.01	0.06	0.02	0.03	0.10	0.04	0.01	0.02	0.02
2026-05-13	0.01	0.02	0.02	0.03	0.04	0.03	0.01	0.07	0.02
2026-05-14	0.02	0.08	0.02	0.03	0.09	0.04	0.01	0.02	0.01
2026-05-15	0.02	0.02	0.02	0.02	0.03	0.03	0.01	0.06	0.02
2026-05-16	0.02	0.09	0.02	0.03	0.12	0.03	0.01	0.02	0.02
2026-05-17	0.02	0.03	0.02	0.03	0.04	0.03	0.01	0.08	0.02
2026-05-18	0.02	0.04	0.02	0.02	0.12	0.03	0.01	0.02	0.01
2026-05-19	0.01	0.07	0.02	0.02	0.03	0.03	0.01	0.07	0.02
2026-05-20	0.01	0.02	0.02	0.03	0.07	0.03	0.01	0.04	0.01
2026-05-21	0.02	0.05	0.02	0.03	0.04	0.03	0.01	0.06	0.02
2026-05-22	0.01	0.02	0.02	0.02	0.07	0.03	0.01	0.01	0.01
2026-05-23	0.01	0.04	0.02	0.02	0.04	0.03	0.01	0.06	0.02
2026-05-24	0.01	0.02	0.01	0.03	0.09	0.03	0.01	0.02	0.01
2026-05-25	0.01	0.04	0.02	0.02	0.04	0.03	0.01	0.05	0.02
2026-05-26	0.01	0.03	0.01	0.03	0.07	0.03	0.01	0.02	0.01
2026-05-27	0.01	0.04	0.02	0.03	0.03	0.03	0.01	0.06	0.02
2026-05-28	0.01	0.02	0.02	0.03	0.07	0.03	0.01	0.02	0.01
2026-05-29	0.01	0.02	0.01	0.02	0.04	0.03	0.01	0.04	0.02
2026-05-30	0.01	0.03	0.02	0.03	0.09	0.04	0.01	0.02	0.02
2026-05-31	0.01	0.03	0.02	0.03	0.05	0.03	0.01	0.02	0.01

Notes:

UV Treatment:

Date	Average Flow (L/s)	Avg Validated Dose (mj/cm2)	UV Availability (%)
2026-05-01	248.51	21.30	99.11
2026-05-02	187.91	21.10	99.93
2026-05-03	257.32	21.10	99.93
2026-05-04	255.68	21.10	99.93
2026-05-05	312.29	21.10	99.93
2026-05-06	367.70	21.10	99.92
2026-05-07	255.74	21.18	99.17
2026-05-08	292.41	21.18	99.93
2026-05-09	166.35	30.28	99.86
2026-05-10	247.49	22.60	99.93
2026-05-11	159.65	30.28	99.93
2026-05-12	281.59	22.28	99.93
2026-05-13	212.21	24.42	99.93
2026-05-14	209.87	25.28	99.93
2026-05-15	159.34	31.95	99.70
2026-05-16	142.90	35.10	75.93
2026-05-17	207.05	25.00	99.93
2026-05-18	223.72	23.67	99.93
2026-05-19	210.62	24.15	99.93
2026-05-20	206.32	26.60	99.93
2026-05-21	261.72	22.42	99.93
2026-05-22	208.60	26.95	99.93
2026-05-23	324.25	21.10	99.93
2026-05-24	244.20	22.90	99.93
2026-05-25	243.39	23.10	99.93
2026-05-26	219.72	25.35	99.93
2026-05-27	294.88	21.90	99.93
2026-05-28	290.62	22.28	99.93
2026-05-29	306.22	99.93	99.93
2026-05-30	169.82	99.88	99.88
2026-05-31	169.71	94.50	94.50

Notes:

May 16 - UV shutdown on low flow

UV Transmittance %:


Date	Min	Max	Average
2026-05-01	86.90	87.40	87.15
2026-05-02	87.00	87.60	87.24
2026-05-03	87.20	87.80	87.45
2026-05-04	87.40	88.50	87.94
2026-05-05	88.50	89.50	89.01
2026-05-06	88.60	89.50	89.07
2026-05-07	88.70	89.50	88.94
2026-05-08	88.90	89.20	89.08
2026-05-09	88.70	89.60	89.15
2026-05-10	88.40	89.20	88.85
2026-05-11	88.40	89.30	88.81
2026-05-12	88.70	89.20	88.97
2026-05-13	89.00	89.70	89.35
2026-05-14	88.70	89.50	89.13
2026-05-15	89.40	90.70	89.71
2026-05-16	89.10	90.00	89.58
2026-05-17	88.60	90.10	89.43
2026-05-18	88.50	89.60	89.21
2026-05-19	88.90	90.00	89.48
2026-05-20	89.60	90.70	90.07
2026-05-21	89.50	90.40	90.11
2026-05-22	89.40	90.70	90.12
2026-05-23	89.70	90.50	90.12
2026-05-24	89.40	90.50	90.04
2026-05-25	89.90	90.80	90.05
2026-05-26	89.90	91.00	90.22
2026-05-27	90.20	90.60	90.41
2026-05-28	89.70	91.20	90.31
2026-05-29	89.10	90.30	89.87
2026-05-30	89.70	90.50	90.04
2026-05-31	90.00	91.70	90.63

Notes:

Chemical Demand:

Chlorine Used:


Total for Month
14956.34 L



Notes:

Caustic Soda Used:

Total for Month
5623.16 Litres




Notes:

Coagulant Used:

Total for Month
23538.23 Litres

Coagulant Usage



Notes:

DAF & Residual DAF Neat Polymer

Total for Month
860.76 L

Centrifuge Neat Polymer

Total for Month
970.41 L

Chlorine Dose


Filtered Water Residual Cl2 Average (mg/L):

1.38 mg/L

Treated Water (Distributed) Cl2 Average (mg/L):

0.93 mg/L

Average Residual Cl2 Content




Water Quality Analytics:

Turbidity


Raw Water Monthly Average:

1.37 NTU



Treated Water Monthly Average:

0.02 NTU



Notes:


pH

Raw Water Monthly Average:

7.98 pH

Treated Water Monthly Average:

7.25 pH



Notes:

Powers Creek WTP Operational Highlights:

NOTE: Lat 1 Flow Meter not working, see trends

May 1st - switched to 4 lamps in UV

May 1st - all six DAFs now running for summer

May 4th - Compressor maintenance by contractor (Wiseworth)

May 8th - greased intake screens & flushed the "Y" strainer

May 11th - cleaned & rinsed CTF poly make down system

May 12th - CWK engineers & contractor doind road survey on intake road

May 19th - Chemical delivery (PAC bulk load)

May 25th - hazard assessment done on old Chlorine building by contractor (NorHaz)

May 25th - intake road graded

May 25th - contractor in to clean plant windows

May 26th - CARE systems service to HVAC computer program

May 28th - installed flashboards on pond Dam

Power Creek Watershed Operational Highlights:

Lambly

May 4th Full pool. First set of flashboards installed

May 12th Second set of flashboards installed level is 2783acft

May 26th Changed Full Cell Level is 2820acft

Jackpine

May 6th level is 877acft

May 26th level is 874acft

Paynter

May 13th Full pool 4" spilling

May 26th Full pool 2" spilling

Powers Creek

May 13th 7.5" over sill 6000usgpm down creek

May 26th 3.75" over sill

Horseshoe

May 6th Full pool 2" spilling

May 26th Full pool 1" spilling

Dobbin

May 6th level is 343acft still filling

May 26th full pool 561acft

Nicola Creek Diversion

May 4th 6" over sill to Dobbin Replaced old flash boards with four new ones

May 26th 2.5" over sill

Tadpole

May 6th level is 2850.6ML fill up good flow from both diversions

May 25th level is 3533.9ML no flow from Sandburg diversion. Completed Piezometers

Dam inspections completed Weekly

Definitions:

UV Availability (%) - Calculated daily percentage of the time the UV is in operation divided by the time where there is flow going through the UV reactor. (Note: SCADA performing this calculation has a small error based on the time the values are pulled which does not allow the UV Availability to show 100% when the Reactor was operating for a full day without interruption (i.e. 99.93% represents a full day running without issue).

WATER DISTRIBUTION



Power's Creek Water Service Area – Distribution System Monitoring

May 2026

Water Quality Data Review

- Based on the Power's Creek Water Service Area distribution system grab sample data, it appears the turbidity, free-chlorine (FCR) and bacteriological results have met the Water Quality Objectives during the month of May.
- May Bacteriological Sampling Summary:
 - 18 samples to CARO for analysis
 - 8 samples analyzed in-house at RWTP
 - All bacteriological sample results were <1 CFU/100mL for Total Coliforms and <1 CFU/100mL for *E.coli*.
- May 6, 2026 – Dixie Reservoir high strength hypo concentration was changed to 5.9% on PLC.
- May 6, 2026 – Glenrosa Reservoir high strength hypo concentration was changed to 8.0% on PLC.
- May 12, 2026 – Quarterly water quality sampling was completed, the certificate of analysis is attached in Appendix A. All parameters measured were within the Guidelines for Canadian Drinking Water Quality.
- May 22, 2026 – Dixie Reservoir high strength hypo concentration was changed to 6.4% on PLC.
- May 28, 2026 – Dixie Reservoir online FCR analyser calibration adjustment of 0.16mg/L decrease.

Operational System Improvements/Events

- May 4, 2026 – Glenrosa Reservoir was receiving low FCR alarms due to treatment plant flow meter malfunctions, alarm limits were changed and will be changes once the flow meter has been replaced.
- May 5, 2026 – 3696 Granada Cres leak on service line affecting one property, repair completed by City staff and City contractor. Positive pressure maintained during repair.
- May 13, 2026 – 3431 Rosedale Plc leak on service line affecting one property, repair completed by City staff and City contractor. Positive pressure maintained during repair.
- May 14, 2026 – Lateral One PS the analog combo card in the PLC for the station was replaced.
- May 14, 2026 – Glenrosa Reservoir maintenance to the security systems was completed.
- May 14, 2026 – 3225 Corral Crt leak on long sided service affecting two properties 3219/3225 Corral Crt, repair completed by City staff. Positive pressure maintained during repair.

WQ Field and SCADA Data

Sampling Location Table:

Sample Name	Civic Address	Pressure Zone	WQ Sampling Rationale
Lateral One PS	3188 Shetler Dr	630	1 st Customer water quality check.
Glenrosa PS	3149 Coventry Cres	673	Mid system water quality check. Water quality distributed throughout Glenrosa area.
Glenrosa Res	3313 Glenrosa Rd	673	Mid system water quality check on reservoir. Re-chlorination occurring at this location.
Smith Creek PS &Res	2802 Smith Creek Rd	630	Mid system water quality check. Water quality distributed throughout Smith Creek and downtown Westbank area.
Dixie Res	2850 Dixie Rd	630	Mid system water quality check. Re-chlorination occurring at this location.
End-of-Line WQS	4119 Gellatly Rd	449	End system water quality check.
Mclver SS	3036 Mclver Rd	626	Mid system water quality check.
Bulk Water Stn	3020 Shannon Lake Rd	583	End system water quality check. Water quality for bulk water filling and free water available to public.


- **PS** = Pump Station
- **SS** = Sample Station
- **Res** = Reservoir
- **WQS** = Water Quality Station

Note: Water Quality (WQ) field data results reflect that of the noted location within the distribution system at the time of the grab sample collection.

Lateral One PS

Lateral One PS Online Data							
Date	pH	Turbidity	Turbidity (Peak 1 Hr)	Temp	FCR		
	Avg (pH)	Avg (NTU)	Max Based On 1 Hr Avg	Avg (°C)	Min (mg/L)	Max (mg/L)	Avg (mg/L)
May 2026							
1	6.32	0.13	0.13	10.12	0.57	0.79	0.71
2	6.27	0.13	0.13	10.77	0.54	0.74	0.70
3	6.25	0.13	0.13	11.29	0.60	0.76	0.71
4	6.25	0.12	0.29	11.93	0.55	0.74	0.68
5	6.17	0.15	0.61	12.16	0.65	0.93	0.87
6	6.11	0.10	0.17	11.70	0.76	0.93	0.87
7	6.20	0.10	0.13	11.95	0.79	0.93	0.87
8	6.21	0.13	0.17	12.06	0.73	0.95	0.86
9	6.19	0.10	0.25	11.08	0.84	0.99	0.93
10	6.23	0.10	0.13	12.02	0.60	0.90	0.83
11	6.21	0.13	0.16	11.89	0.62	0.88	0.80
12	6.28	0.10	0.17	12.42	0.72	0.90	0.84
13	6.18	0.09	0.26	12.33	0.63	0.93	0.82
14	6.52	0.07	0.07	12.59	0.43	0.78	0.65
15	6.32	0.07	0.08	10.56	0.25	0.79	0.66
16	6.43	0.08	0.09	9.48	0.03	0.89	0.68
17	6.32	0.09	0.10	9.32	0.42	0.87	0.68
18	6.33	0.10	0.11	9.83	0.39	0.93	0.76
19	6.33	0.11	0.11	10.56	0.42	0.92	0.78
20	6.21	0.11	0.12	10.90	0.71	0.95	0.87
21	6.20	0.12	0.13	11.60	0.71	0.90	0.82
22	6.17	0.13	0.14	11.56	0.65	0.85	0.79
23	6.12	0.14	0.15	12.80	0.67	0.92	0.83
24	6.13	0.15	0.15	13.63	0.65	0.86	0.79
25	6.11	0.15	0.16	14.23	0.60	0.79	0.73
26	6.13	0.16	0.17	13.81	0.65	0.86	0.80
27	6.06	0.12	0.37	13.09	0.71	0.93	0.85
28	6.05	0.05	0.05	14.09	0.69	0.87	0.82
29	6.15	0.05	0.05	15.71	0.40	0.79	0.67
30	6.14	0.05	0.05	13.96	0.43	0.74	0.64
31	6.11	0.05	0.05	12.97	0.55	0.83	0.73
Average	6.22	0.11		12.01	0.58	0.87	0.78
Min	6.05	0.05		9.32	0.03	0.74	0.64
Max	6.52	0.16	0.61	15.71	0.84	0.99	0.93

Lateral One PS Online Data



Lateral One PS Water Quality


Date	Turbidity		Temp	FCR		pH
	Grab (NTU)	Online (NTU)	Grab (°C)	Grab (mg/L)	Online (mg/L)	
05-May-26	0.21	0.08	14.1	1	0.84	7.21
12-May-26	0.06	0.07	10.1	0.88	0.9	7.16
19-May-26	0.06	0.07	11.1	0.95	0.86	7
26-May-26	0.11		13.2	0.91		7.02
# of Samples	4	3	4	4	3	4
Average	0.11	0.07	12.13	0.94	0.87	7.1
Range	0.06-0.21	0.07-0.08	10.1-14.1	0.88-1	0.84-0.9	7-7.21

Glenrosa PS & Reservoir

Glenrosa Reservoir Online Data							
Date	Flow Total From PS	Peak Flow From PS	pH	Temp	FCR		
	(ML)	Max (ML/Day)	Avg (pH)	Avg (°C)	Min (mg/L)	Max (mg/L)	Avg (mg/L)
May 2026							
1	2.82	4.13	6.96	7.85	0.23	0.73	0.47
2	3.27	4.14	6.97	8.26	0.20	0.71	0.47
3	3.52	4.15	6.96	8.57	0.17	0.73	0.48
4	2.90	4.12	6.98	9.00	0.14	0.73	0.44
5	3.41	5.04	6.93	8.87	0.13	0.88	0.41
6	3.42	5.06	6.91	9.45	0.18	0.83	0.54
7	3.15	5.05	6.93	9.90	0.24	0.88	0.57
8	2.93	5.06	6.95	10.20	0.28	0.90	0.58
9	3.76	5.06	6.96	9.87	0.30	0.95	0.61
10	3.27	5.06	6.97	10.23	0.32	0.88	0.59
11	3.04	5.05	6.99	10.41	0.31	0.87	0.59
12	3.53	5.06	6.98	10.33	0.32	0.89	0.57
13	3.08	5.06	6.99	10.47	0.31	0.91	0.52
14	2.54	5.07	7.06	10.22	0.33	0.82	0.54
15	2.59	5.07	7.10	9.89	0.37	0.89	0.57
16	2.90	5.05	7.15	9.33	0.38	1.03	0.60
17	2.92	5.09	7.20	8.98	0.38	0.92	0.57
18	2.85	5.07	7.14	9.03	0.38	0.97	0.62
19	3.42	5.06	7.13	9.28	0.40	0.92	0.61
20	3.06	5.09	7.09	9.40	0.38	0.94	0.63
21	2.96	5.07	7.07	9.82	0.35	0.91	0.62
22	2.85	5.06	7.06	9.86	0.38	0.86	0.61
23	3.94	8.79	7.03	10.46	0.34	0.89	0.61
24	3.78	5.06	7.04	10.86	0.32	0.87	0.57
25	2.95	5.06	7.04	11.40	0.32	0.82	0.56
26	3.14	5.06	7.04	11.39	0.29	0.85	0.49
27	3.46	5.06	7.04	11.33	0.32	0.91	0.58
28	3.16	5.05	7.02	11.71	0.32	0.88	0.66
29	2.51	4.10	7.05	12.35	0.27	0.80	0.50
30	3.08	8.74	7.09	12.07	0.26	0.83	0.48
31	3.13	5.06	7.08	11.76	0.33	0.91	0.57
Total	95						
Average	3.14	5.15	7.03	10.08	0.30	0.87	0.56
Min	2.51	4.10	6.91	7.85	0.13	0.71	0.41
Max	3.94	8.79	7.20	12.35	0.40	1.03	0.66

Glenrosa Reservoir Online Data

Free Chlorine Residual (mg/L)




Smith Creek PS, Dixie Reservoir & End-of-Line WQS

Date	Smith Creek Reservoir FCR		
	Min (mg/L)	Max (mg/L)	Avg (mg/L)
May 2026			
1	0.32	0.84	0.58
2	0.29	0.81	0.57
3	0.25	0.83	0.51
4	0.23	0.81	0.52
5	0.21	0.99	0.52
6	0.26	0.97	0.59
7	0.29	0.99	0.67
8	0.26	0.99	0.62
9	0.30	1.05	0.68
10	0.34	0.97	0.61
11	0.34	0.95	0.64
12	0.34	0.97	0.63
13	0.35	1.01	0.62
14	0.40	0.86	0.53
15	0.34	0.88	0.53
16	0.37	0.95	0.57
17	0.30	0.95	0.54
18	0.36	1.05	0.62
19	0.40	1.01	0.64
20	0.36	1.03	0.72
21	0.45	0.99	0.69
22	0.43	0.94	0.71
23	0.41	0.99	0.69
24	0.40	0.94	0.67
25	0.40	0.90	0.63
26	0.37	0.94	0.63
27	0.36	1.01	0.64
28	0.37	0.97	0.68
29	0.36	0.90	0.56
30	0.36	0.86	0.49
31	0.36	0.92	0.53
Average	0.34	0.94	0.61
Min	0.21	0.81	0.49
Max	0.45	1.05	0.72

Dixie Reservoir FCR		
Min (mg/L)	Max (mg/L)	Avg (mg/L)
0.41	0.55	0.50
0.51	0.61	0.52
0.56	0.61	0.59
0.56	0.68	0.64
0.61	0.65	0.63
0.59	0.90	0.78
0.81	0.86	0.85
0.81	0.92	0.89
0.81	0.94	0.86
0.87	0.94	0.90
0.84	0.94	0.89
0.85	0.92	0.89
0.85	0.97	0.89
0.88	0.96	0.93
0.84	0.92	0.87
0.86	0.92	0.89
0.80	0.86	0.84
0.72	0.80	0.77
0.54	0.81	0.70
0.63	0.70	0.66
0.59	0.65	0.63
0.58	0.66	0.62
0.56	0.63	0.60
0.55	0.64	0.61
0.59	0.72	0.65
0.62	0.68	0.65
0.47	0.68	0.57
0.45	0.59	0.52
0.54	0.64	0.57
0.62	0.68	0.64
0.58	0.64	0.62
0.66	0.76	0.72
0.41	0.55	0.50
0.88	0.97	0.93

End of The Line FCR		
Min (mg/L)	Max (mg/L)	Avg (mg/L)
0.39	0.54	0.48
0.46	0.76	0.54
0.46	0.56	0.51
0.34	0.54	0.44
0.30	0.65	0.54
0.43	0.67	0.61
0.50	0.66	0.62
0.38	0.67	0.53
0.42	0.81	0.70
0.57	0.79	0.69
0.50	0.64	0.56
0.41	0.68	0.59
0.50	0.66	0.59
0.45	0.58	0.52
0.37	0.52	0.46
0.37	0.61	0.49
0.39	0.67	0.53
0.42	0.61	0.50
0.35	0.76	0.66
0.53	0.76	0.67
0.64	0.78	0.72
0.51	0.64	0.59
0.50	0.71	0.63
0.60	0.70	0.65
0.48	0.61	0.56
0.44	0.68	0.57
0.45	0.66	0.57
0.60	0.73	0.66
0.46	0.60	0.54
0.34	0.55	0.44
0.33	0.53	0.47
0.45	0.66	0.57
0.30	0.52	0.44
0.64	0.81	0.72

Smith Creek/Dixie/End of Line Online Data



End-of-Line WQS Water Quality

Date	Turbidity	Temp	FCR		pH
	Grab (NTU)	Grab (°C)	Grab (mg/L)	Online (mg/L)	
05-May-26	0.25	12.8	0.69	0.56	7.36
12-May-26	0.11	13.5	0.59	0.57	7.09
19-May-26	0.10	13.4	0.62	0.69	7.03
26-May-26	0.09	14.1	0.65	0.67	7.46
# of Samples	4	4	4	4	4
Average	0.14	13.45	0.64	0.62	7.24
Range	0.09-0.25	12.8-14.1	0.59-0.69	0.56-0.69	7.03-7.46

WQ Field Data

Mclver SS

Mclver SS Water Quality				
Date	Turbidity	Temp	FCR	pH
	Grab (NTU)	Grab (°C)	Grab (mg/L)	
05-May-26	0.19	12.0	0.59	7.30
12-May-26	0.11	11.4	0.76	7.06
19-May-26	0.09	11.1	0.77	7.02
26-May-26	0.08	13.2	0.91	7.03
# of Samples	4	4	4	4
Average	0.12	11.9	0.76	7.1
Range	0.08-0.19	11.1-13.2	0.59-0.91	7.02-7.3

Bulk Water Station (Stn)

Bulk Water Station Water Quality				
Date	Turbidity	Temp	FCR	pH
	Grab (NTU)	Grab (°C)	Grab (mg/L)	
05-May-26	0.60	12.6	0.51	7.13
12-May-26	0.19	11.9	0.71	7.03
19-May-26	0.11	12.3	0.77	7.02
26-May-26	0.10	14.2	0.70	7.03
# of Samples	4	4	4	4
Average	0.25	12.75	0.67	7.05
Range	0.10-0.6	11.9-14.2	0.51-0.77	7.02-7.13

Disinfection Byproducts

Powers Creek Water Service Area - THM Results (mg/L) MAC=0.10mg/L

Date	Lateral One PS	End-of-Line	Mclver SS	Bulk Water Stn
19-Aug-25	0.0376	0.0365	0.0318	0.0574
25-Nov-25	0.0400	0.0475	0.0420	0.0541
9-Dec-25	0.0227	0.0293	0.0308	0.0307
17-Feb-26	0.0344	0.0483	0.0516	0.0450
12-May-26	0.0264	0.0420	0.0369	0.0347
Average	0.0322	0.0407	0.0386	0.0444

Powers Creek Water Service Area - HAA5 Results (mg/L) MAC=0.08mg/L

Date	Lateral One PS	End-of-Line	Mclver SS	Bulk Water Stn
19-Aug-25	0.0205	0.0312	0.0318	0.0277
25-Nov-25	0.0280	0.0359	0.0325	0.0376
9-Dec-25	0.0221	0.0342	0.0341	0.0349
17-Feb-26	0.0184	0.0248	0.0310	0.0268
12-May-26	0.0207	0.0336	0.0302	0.0260
Average	0.0219	0.0319	0.0319	0.0306

Manganese

Power's Creek Water Service Area - Manganese Results (mg/L)

Location	19-Aug-25	25-Nov-25	17-Feb-26	12-May-26	Average
Lateral One PS	0.00421	0.00500	0.00343	0.00387	0.00413
Mclver SS	0.00174	0.00294	0.00214	0.00236	0.00230
End-of-Line	0.00158	0.00163	0.00086	0.00442	0.00212
Bulk Water Stn	0.00569	0.00191	0.00225	0.00643	0.00407

*MAC=0.12mg/L & AO=0.02mg/L

Appendix A – Quarterly Certificate of Analysis



TEST RESULTS

REPORTED TO PROJECT West Kelowna, City of
Powers Creek Water Service Area - General

WORK ORDER REPORTED 26E1386
2026-05-22 13:37

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
LATERAL ONE PS (26E1386-01) Matrix: Drinking Water Sampled: 2026-05-12 10:40						
Calculated Parameters						
Total Trihalomethanes	0.0264	MAC = 0.1	0.00400	mg/L	N/A	
Hardness, Total (as CaCO3)	39.6	None Required	0.500	mg/L	N/A	
Langelier Index	-1.7	N/A	-5.0		2026-05-20	CT9
Nitrogen, Organic	< 0.0500	N/A	0.0500	mg/L	N/A	
Field Parameters						
Chlorine, Free	0.88	N/A	0.02	mg/L	2026-05-12	
pH	7.2	7.0-10.5	0.1	pH units	2026-05-12	
Turbidity	< 0.10	OG < 1	0.10	NTU	2026-05-12	
General Parameters						
Alkalinity, Total (as CaCO3)	36.8	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Phenolphthalein (as CaCO3)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Bicarbonate (as CaCO3)	36.8	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Carbonate (as CaCO3)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Hydroxide (as CaCO3)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Ammonia, Total (as N)	< 0.050	None Required	0.050	mg/L	2026-05-15	
Carbon, Total Organic	3.74	N/A	0.50	mg/L	2026-05-15	
Nitrogen, Total Kjeldahl	< 0.050	N/A	0.050	mg/L	2026-05-20	
Solids, Total Dissolved	99	AO ≤ 500	15	mg/L	2026-05-19	
Temperature, at pH	21.5	N/A		°C	2026-05-13	HT2
Haloacetic Acids						
Monochloroacetic Acid	< 0.0030	N/A	0.0020	mg/L	2026-05-20	RA3
Monobromoacetic Acid	< 0.0020	N/A	0.0020	mg/L	2026-05-20	
Dichloroacetic Acid	0.0113	N/A	0.0020	mg/L	2026-05-20	
Trichloroacetic Acid	0.0093	N/A	0.0020	mg/L	2026-05-20	
Dibromoacetic Acid	< 0.0020	N/A	0.0020	mg/L	2026-05-20	
Total Haloacetic Acids (HAA5)	0.0207	MAC = 0.08	0.00304	mg/L	N/A	
Surrogate: 2-Bromopropionic Acid	106		70-130	%	2026-05-20	
Microbiological Parameters						
Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	2026-05-12	
E. coli	< 1	MAC = 0	1	CFU/100 mL	2026-05-12	
Total Metals						
Aluminum, total	0.0159	OG < 0.1	0.0050	mg/L	2026-05-14	
Antimony, total	< 0.00020	MAC = 0.006	0.00020	mg/L	2026-05-14	
Arsenic, total	< 0.00050	MAC = 0.01	0.00050	mg/L	2026-05-14	
Barium, total	0.0130	MAC = 2	0.0050	mg/L	2026-05-14	
Beryllium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Bismuth, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Boron, total	< 0.0500	MAC = 5	0.0500	mg/L	2026-05-14	
Cadmium, total	< 0.000010	MAC = 0.007	0.000010	mg/L	2026-05-14	
Calcium, total	12.9	None Required	0.20	mg/L	2026-05-14	



TEST RESULTS

REPORTED TO PROJECT West Kelowna, City of Powers Creek Water Service Area - General

WORK ORDER REPORTED 26E1386 2026-05-22 13:37

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
---------	--------	-----------	----	-------	----------	-----------

LATERAL ONE PS (26E1386-01) | Matrix: Drinking Water | Sampled: 2026-05-12 10:40, Continued

Total Metals, Continued

Chromium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2026-05-14	
Cobalt, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Copper, total	0.00042	MAC = 2	0.00040	mg/L	2026-05-14	
Iron, total	< 0.010	AO ≤ 0.1	0.010	mg/L	2026-05-14	
Lead, total	< 0.00020	MAC = 0.005	0.00020	mg/L	2026-05-14	
Lithium, total	0.00070	N/A	0.00010	mg/L	2026-05-14	
Magnesium, total	1.77	None Required	0.010	mg/L	2026-05-14	
Manganese, total	0.00387	MAC = 0.12	0.00020	mg/L	2026-05-14	
Molybdenum, total	0.00083	N/A	0.00010	mg/L	2026-05-14	
Nickel, total	< 0.00040	N/A	0.00040	mg/L	2026-05-14	
Phosphorus, total	< 0.050	N/A	0.050	mg/L	2026-05-14	
Potassium, total	1.10	N/A	0.10	mg/L	2026-05-14	
Selenium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2026-05-14	
Silicon, total	6.4	N/A	1.0	mg/L	2026-05-14	
Silver, total	< 0.000050	None Required	0.000050	mg/L	2026-05-14	
Sodium, total	4.74	AO ≤ 200	0.10	mg/L	2026-05-14	
Strontium, total	0.0491	MAC = 7	0.0010	mg/L	2026-05-14	
Sulfur, total	< 3.0	N/A	3.0	mg/L	2026-05-14	
Tellurium, total	< 0.00050	N/A	0.00050	mg/L	2026-05-14	
Thallium, total	< 0.000020	N/A	0.000020	mg/L	2026-05-14	
Thorium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Tin, total	< 0.00020	N/A	0.00020	mg/L	2026-05-14	
Titanium, total	< 0.0050	N/A	0.0050	mg/L	2026-05-14	
Tungsten, total	< 0.0010	N/A	0.0010	mg/L	2026-05-14	
Uranium, total	< 0.000020	MAC = 0.02	0.000020	mg/L	2026-05-14	
Vanadium, total	< 0.0050	N/A	0.0050	mg/L	2026-05-14	
Zinc, total	< 0.0040	AO ≤ 5	0.0040	mg/L	2026-05-14	
Zirconium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	

Volatile Organic Compounds (VOC)

Bromodichloromethane	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Bromoform	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Chloroform	0.0264	N/A	0.0010	mg/L	2026-05-15	
Dibromochloromethane	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Surrogate: Toluene-d8	86		70-130	%	2026-05-15	
Surrogate: 4-Bromofluorobenzene	84		70-130	%	2026-05-15	

MCIVER SS (26E1386-02) | Matrix: Drinking Water | Sampled: 2026-05-12 09:45

Calculated Parameters

Total Trihalomethanes	0.0369	MAC = 0.1	0.00400	mg/L	N/A	
Hardness, Total (as CaCO3)	39.4	None Required	0.500	mg/L	N/A	
Langelier Index	-1.8	N/A	-5.0		2026-05-20	CT9



TEST RESULTS

REPORTED TO PROJECT West Kelowna, City of
Powers Creek Water Service Area - General

WORK ORDER REPORTED 26E1386
2026-05-22 13:37

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
MCIVER SS (26E1386-02) Matrix: Drinking Water Sampled: 2026-05-12 09:45, Continued						
Field Parameters						
Chlorine, Free	0.76	N/A	0.02	mg/L	2026-05-12	
pH	7.1	7.0-10.5	0.1	pH units	2026-05-12	
Turbidity	0.11	OG < 1	0.10	NTU	2026-05-12	
General Parameters						
Alkalinity, Total (as CaCO ₃)	34.7	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Phenolphthalein (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Bicarbonate (as CaCO ₃)	34.7	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Carbonate (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Hydroxide (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Carbon, Total Organic	4.32	N/A	0.50	mg/L	2026-05-15	
Solids, Total Dissolved	111	AO ≤ 500	15	mg/L	2026-05-19	
Temperature, at pH	21.4	N/A		°C	2026-05-13	HT2
Haloacetic Acids						
Monochloroacetic Acid	< 0.0035	N/A	0.0020	mg/L	2026-05-20	RA3
Monobromoacetic Acid	< 0.0020	N/A	0.0020	mg/L	2026-05-20	
Dichloroacetic Acid	0.0154	N/A	0.0020	mg/L	2026-05-20	
Trichloroacetic Acid	0.0149	N/A	0.0020	mg/L	2026-05-20	
Dibromoacetic Acid	< 0.0020	N/A	0.0020	mg/L	2026-05-20	
Total Haloacetic Acids (HAA5)	0.0302	MAC = 0.08	0.00352	mg/L	N/A	
Surrogate: 2-Bromopropionic Acid	108		70-130	%	2026-05-20	
Microbiological Parameters						
Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	2026-05-12	
E. coli	< 1	MAC = 0	1	CFU/100 mL	2026-05-12	
Total Metals						
Aluminum, total	0.0137	OG < 0.1	0.0050	mg/L	2026-05-14	
Antimony, total	< 0.00020	MAC = 0.006	0.00020	mg/L	2026-05-14	
Arsenic, total	< 0.00050	MAC = 0.01	0.00050	mg/L	2026-05-14	
Barium, total	0.0128	MAC = 2	0.0050	mg/L	2026-05-14	
Beryllium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Bismuth, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Boron, total	< 0.0500	MAC = 5	0.0500	mg/L	2026-05-14	
Cadmium, total	< 0.000010	MAC = 0.007	0.000010	mg/L	2026-05-14	
Calcium, total	12.8	None Required	0.20	mg/L	2026-05-14	
Chromium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2026-05-14	
Cobalt, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Copper, total	0.00191	MAC = 2	0.00040	mg/L	2026-05-14	
Iron, total	< 0.010	AO ≤ 0.1	0.010	mg/L	2026-05-14	
Lead, total	< 0.00020	MAC = 0.005	0.00020	mg/L	2026-05-14	
Lithium, total	0.00070	N/A	0.00010	mg/L	2026-05-14	
Magnesium, total	1.78	None Required	0.010	mg/L	2026-05-14	



TEST RESULTS

REPORTED TO PROJECT West Kelowna, City of Powers Creek Water Service Area - General

WORK ORDER REPORTED 26E1386 2026-05-22 13:37

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
---------	--------	-----------	----	-------	----------	-----------

MCIVER SS (26E1386-02) | Matrix: Drinking Water | Sampled: 2026-05-12 09:45, Continued

Total Metals, Continued

Manganese, total	0.00236	MAC = 0.12	0.00020	mg/L	2026-05-14	
Molybdenum, total	0.00082	N/A	0.00010	mg/L	2026-05-14	
Nickel, total	< 0.00040	N/A	0.00040	mg/L	2026-05-14	
Phosphorus, total	< 0.050	N/A	0.050	mg/L	2026-05-14	
Potassium, total	1.10	N/A	0.10	mg/L	2026-05-14	
Selenium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2026-05-14	
Silicon, total	6.4	N/A	1.0	mg/L	2026-05-14	
Silver, total	< 0.000050	None Required	0.000050	mg/L	2026-05-14	
Sodium, total	4.63	AO ≤ 200	0.10	mg/L	2026-05-14	
Strontium, total	0.0499	MAC = 7	0.0010	mg/L	2026-05-14	
Sulfur, total	< 3.0	N/A	3.0	mg/L	2026-05-14	
Tellurium, total	< 0.00050	N/A	0.00050	mg/L	2026-05-14	
Thallium, total	< 0.000020	N/A	0.000020	mg/L	2026-05-14	
Thorium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Tin, total	< 0.00020	N/A	0.00020	mg/L	2026-05-14	
Titanium, total	< 0.0050	N/A	0.0050	mg/L	2026-05-14	
Tungsten, total	< 0.0010	N/A	0.0010	mg/L	2026-05-14	
Uranium, total	< 0.000020	MAC = 0.02	0.000020	mg/L	2026-05-14	
Vanadium, total	< 0.0050	N/A	0.0050	mg/L	2026-05-14	
Zinc, total	< 0.0040	AO ≤ 5	0.0040	mg/L	2026-05-14	
Zirconium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	

Volatile Organic Compounds (VOC)

Bromodichloromethane	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Bromoform	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Chloroform	0.0369	N/A	0.0010	mg/L	2026-05-15	
Dibromochloromethane	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Surrogate: Toluene-d8	90		70-130	%	2026-05-15	
Surrogate: 4-Bromofluorobenzene	88		70-130	%	2026-05-15	

END OF LINE WQS (26E1386-03) | Matrix: Drinking Water | Sampled: 2026-05-12 09:05

Calculated Parameters

Total Trihalomethanes	0.0420	MAC = 0.1	0.00400	mg/L	N/A	
Hardness, Total (as CaCO3)	37.4	None Required	0.500	mg/L	N/A	
Langelier Index	-1.7	N/A	-5.0		2026-05-15	CT9

Field Parameters

Chlorine, Free	0.59	N/A	0.02	mg/L	2026-05-12	
pH	7.1	7.0-10.5	0.1	pH units	2026-05-12	
Turbidity	0.11	OG < 1	0.10	NTU	2026-05-12	

General Parameters

Alkalinity, Total (as CaCO3)	40.3	N/A	1.0	mg/L	2026-05-13	
------------------------------	------	-----	-----	------	------------	--



TEST RESULTS

REPORTED TO PROJECT West Kelowna, City of
Powers Creek Water Service Area - General

WORK ORDER REPORTED 26E1386
2026-05-22 13:37

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
END OF LINE WQS (26E1386-03) Matrix: Drinking Water Sampled: 2026-05-12 09:05, Continued					
<i>General Parameters, Continued</i>					
Alkalinity, Phenolphthalein (as CaCO ₃)	< 1.0	N/A	1.0 mg/L	2026-05-13	
Alkalinity, Bicarbonate (as CaCO ₃)	40.3	N/A	1.0 mg/L	2026-05-13	
Alkalinity, Carbonate (as CaCO ₃)	< 1.0	N/A	1.0 mg/L	2026-05-13	
Alkalinity, Hydroxide (as CaCO ₃)	< 1.0	N/A	1.0 mg/L	2026-05-13	
Carbon, Total Organic	3.65	N/A	0.50 mg/L	2026-05-15	
Solids, Total Dissolved	70	AO ≤ 500	15 mg/L	2026-05-14	
Temperature, at pH	21.5	N/A	°C	2026-05-13	HT2
<i>Haloacetic Acids</i>					
Monochloroacetic Acid	< 0.0030	N/A	0.0020 mg/L	2026-05-20	RA3
Monobromoacetic Acid	< 0.0020	N/A	0.0020 mg/L	2026-05-20	
Dichloroacetic Acid	0.0161	N/A	0.0020 mg/L	2026-05-20	
Trichloroacetic Acid	0.0175	N/A	0.0020 mg/L	2026-05-20	
Dibromoacetic Acid	< 0.0020	N/A	0.0020 mg/L	2026-05-20	
Total Haloacetic Acids (HAA5)	0.0336	MAC = 0.08	0.00299 mg/L	N/A	
Surrogate: 2-Bromopropionic Acid	108		70-130 %	2026-05-20	
<i>Microbiological Parameters</i>					
Coliforms, Total	< 1	MAC = 0	1 CFU/100 mL	2026-05-12	
E. coli	< 1	MAC = 0	1 CFU/100 mL	2026-05-12	
<i>Total Metals</i>					
Aluminum, total	0.0117	OG < 0.1	0.0050 mg/L	2026-05-14	
Antimony, total	< 0.00020	MAC = 0.006	0.00020 mg/L	2026-05-14	
Arsenic, total	< 0.00050	MAC = 0.01	0.00050 mg/L	2026-05-14	
Barium, total	0.0126	MAC = 2	0.0050 mg/L	2026-05-14	
Beryllium, total	< 0.00010	N/A	0.00010 mg/L	2026-05-14	
Bismuth, total	< 0.00010	N/A	0.00010 mg/L	2026-05-14	
Boron, total	< 0.0500	MAC = 5	0.0500 mg/L	2026-05-14	
Cadmium, total	< 0.000010	MAC = 0.007	0.000010 mg/L	2026-05-14	
Calcium, total	12.3	None Required	0.20 mg/L	2026-05-14	
Chromium, total	< 0.00050	MAC = 0.05	0.00050 mg/L	2026-05-14	
Cobalt, total	< 0.00010	N/A	0.00010 mg/L	2026-05-14	
Copper, total	0.00553	MAC = 2	0.00040 mg/L	2026-05-14	
Iron, total	< 0.010	AO ≤ 0.1	0.010 mg/L	2026-05-14	
Lead, total	0.00055	MAC = 0.005	0.00020 mg/L	2026-05-14	
Lithium, total	0.00065	N/A	0.00010 mg/L	2026-05-14	
Magnesium, total	1.59	None Required	0.010 mg/L	2026-05-14	
Manganese, total	0.00442	MAC = 0.12	0.00020 mg/L	2026-05-14	
Molybdenum, total	0.00083	N/A	0.00010 mg/L	2026-05-14	
Nickel, total	< 0.00040	N/A	0.00040 mg/L	2026-05-14	
Phosphorus, total	< 0.050	N/A	0.050 mg/L	2026-05-14	
Potassium, total	1.02	N/A	0.10 mg/L	2026-05-14	
Selenium, total	< 0.00050	MAC = 0.05	0.00050 mg/L	2026-05-14	



TEST RESULTS

REPORTED TO PROJECT West Kelowna, City of Powers Creek Water Service Area - General

WORK ORDER REPORTED 26E1386 2026-05-22 13:37

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
---------	--------	-----------	----	-------	----------	-----------

END OF LINE WQS (26E1386-03) | Matrix: Drinking Water | Sampled: 2026-05-12 09:05, Continued

Total Metals, Continued

Silicon, total	5.9	N/A	1.0	mg/L	2026-05-14	
Silver, total	< 0.000050	None Required	0.000050	mg/L	2026-05-14	
Sodium, total	4.54	AO ≤ 200	0.10	mg/L	2026-05-14	
Strontium, total	0.0502	MAC = 7	0.0010	mg/L	2026-05-14	
Sulfur, total	< 3.0	N/A	3.0	mg/L	2026-05-14	
Tellurium, total	< 0.00050	N/A	0.00050	mg/L	2026-05-14	
Thallium, total	< 0.000020	N/A	0.000020	mg/L	2026-05-14	
Thorium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	
Tin, total	< 0.00020	N/A	0.00020	mg/L	2026-05-14	
Titanium, total	< 0.0050	N/A	0.0050	mg/L	2026-05-14	
Tungsten, total	< 0.0010	N/A	0.0010	mg/L	2026-05-14	
Uranium, total	< 0.000020	MAC = 0.02	0.000020	mg/L	2026-05-14	
Vanadium, total	< 0.0050	N/A	0.0050	mg/L	2026-05-14	
Zinc, total	< 0.0040	AO ≤ 5	0.0040	mg/L	2026-05-14	
Zirconium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-14	

Volatile Organic Compounds (VOC)

Bromodichloromethane	0.0012	N/A	0.0010	mg/L	2026-05-15	
Bromoform	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Chloroform	0.0408	N/A	0.0010	mg/L	2026-05-15	
Dibromochloromethane	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Surrogate: Toluene-d8	89		70-130	%	2026-05-15	
Surrogate: 4-Bromofluorobenzene	87		70-130	%	2026-05-15	

BULK WATER STN (26E1386-04) | Matrix: Drinking Water | Sampled: 2026-05-12 11:07

Calculated Parameters

Total Trihalomethanes	0.0347	MAC = 0.1	0.00400	mg/L	N/A	
Hardness, Total (as CaCO3)	41.1	None Required	0.500	mg/L	N/A	
Langelier Index	-1.8	N/A	-5.0		2026-05-20	CT9

Field Parameters

Chlorine, Free	0.71	N/A	0.02	mg/L	2026-05-12	
pH	7.0	7.0-10.5	0.1	pH units	2026-05-12	
Turbidity	0.19	OG < 1	0.10	NTU	2026-05-12	

General Parameters

Alkalinity, Total (as CaCO3)	35.3	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Phenolphthalein (as CaCO3)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Bicarbonate (as CaCO3)	35.3	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Carbonate (as CaCO3)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Alkalinity, Hydroxide (as CaCO3)	< 1.0	N/A	1.0	mg/L	2026-05-13	
Carbon, Total Organic	3.84	N/A	0.50	mg/L	2026-05-15	
Solids, Total Dissolved	103	AO ≤ 500	15	mg/L	2026-05-19	



TEST RESULTS

REPORTED TO PROJECT West Kelowna, City of Powers Creek Water Service Area - General

WORK ORDER REPORTED 26E1386 2026-05-22 13:37

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
BULK WATER STN (26E1386-04) Matrix: Drinking Water Sampled: 2026-05-12 11:07, Continued						
<i>General Parameters, Continued</i>						
Temperature, at pH	21.9	N/A		°C	2026-05-13	HT2
<i>Haloacetic Acids</i>						
Monochloroacetic Acid	< 0.0031	N/A	0.0020	mg/L	2026-05-20	RA3
Monobromoacetic Acid	< 0.0020	N/A	0.0020	mg/L	2026-05-20	
Dichloroacetic Acid	0.0129	N/A	0.0020	mg/L	2026-05-20	
Trichloroacetic Acid	0.0131	N/A	0.0020	mg/L	2026-05-20	
Dibromoacetic Acid	< 0.0020	N/A	0.0020	mg/L	2026-05-20	
Total Haloacetic Acids (HAA5)	0.0260	MAC = 0.08	0.00314	mg/L	N/A	
Surrogate: 2-Bromopropionic Acid	110		70-130	%	2026-05-20	
<i>Microbiological Parameters</i>						
Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	2026-05-12	
E. coli	< 1	MAC = 0	1	CFU/100 mL	2026-05-12	
<i>Total Metals</i>						
Aluminum, total	0.0161	OG < 0.1	0.0050	mg/L	2026-05-16	
Antimony, total	< 0.00020	MAC = 0.006	0.00020	mg/L	2026-05-16	
Arsenic, total	< 0.00050	MAC = 0.01	0.00050	mg/L	2026-05-16	
Barium, total	0.0131	MAC = 2	0.0050	mg/L	2026-05-16	
Beryllium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-16	
Bismuth, total	< 0.00010	N/A	0.00010	mg/L	2026-05-16	
Boron, total	< 0.0500	MAC = 5	0.0500	mg/L	2026-05-16	
Cadmium, total	< 0.000010	MAC = 0.007	0.000010	mg/L	2026-05-16	
Calcium, total	13.5	None Required	0.20	mg/L	2026-05-16	
Chromium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2026-05-16	
Cobalt, total	< 0.00010	N/A	0.00010	mg/L	2026-05-16	
Copper, total	0.00061	MAC = 2	0.00040	mg/L	2026-05-16	
Iron, total	< 0.010	AO ≤ 0.1	0.010	mg/L	2026-05-16	
Lead, total	0.00041	MAC = 0.005	0.00020	mg/L	2026-05-16	
Lithium, total	0.00074	N/A	0.00010	mg/L	2026-05-16	
Magnesium, total	1.78	None Required	0.010	mg/L	2026-05-16	
Manganese, total	0.00643	MAC = 0.12	0.00020	mg/L	2026-05-16	
Molybdenum, total	0.00080	N/A	0.00010	mg/L	2026-05-16	
Nickel, total	0.00065	N/A	0.00040	mg/L	2026-05-16	
Phosphorus, total	< 0.050	N/A	0.050	mg/L	2026-05-16	
Potassium, total	1.09	N/A	0.10	mg/L	2026-05-16	
Selenium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2026-05-16	
Silicon, total	6.4	N/A	1.0	mg/L	2026-05-16	
Silver, total	< 0.000050	None Required	0.000050	mg/L	2026-05-16	
Sodium, total	4.54	AO ≤ 200	0.10	mg/L	2026-05-16	
Strontium, total	0.0472	MAC = 7	0.0010	mg/L	2026-05-16	
Sulfur, total	< 3.0	N/A	3.0	mg/L	2026-05-16	
Tellurium, total	< 0.00050	N/A	0.00050	mg/L	2026-05-16	



TEST RESULTS

REPORTED TO PROJECT West Kelowna, City of Powers Creek Water Service Area - General

WORK ORDER REPORTED 26E1386 2026-05-22 13:37

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
BULK WATER STN (26E1386-04) Matrix: Drinking Water Sampled: 2026-05-12 11:07, Continued						
Total Metals, Continued						
Thallium, total	< 0.000020	N/A	0.000020	mg/L	2026-05-16	
Thorium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-16	
Tin, total	< 0.00020	N/A	0.00020	mg/L	2026-05-16	
Titanium, total	< 0.0050	N/A	0.0050	mg/L	2026-05-16	
Tungsten, total	< 0.0010	N/A	0.0010	mg/L	2026-05-16	
Uranium, total	< 0.000020	MAC = 0.02	0.000020	mg/L	2026-05-16	
Vanadium, total	< 0.0050	N/A	0.0050	mg/L	2026-05-16	
Zinc, total	< 0.0040	AO ≤ 5	0.0040	mg/L	2026-05-16	
Zirconium, total	< 0.00010	N/A	0.00010	mg/L	2026-05-16	
Volatile Organic Compounds (VOC)						
Bromodichloromethane	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Bromoform	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Chloroform	0.0347	N/A	0.0010	mg/L	2026-05-15	
Dibromochloromethane	< 0.0010	N/A	0.0010	mg/L	2026-05-15	
Surrogate: Toluene-d8	90		70-130	%	2026-05-15	
Surrogate: 4-Bromofluorobenzene	90		70-130	%	2026-05-15	

Sample Qualifiers:

CT9 Results were based on lab temperature.
 HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.
 RA3 The Reporting Limit has been raised due to comparable level detected in the blank(s).